

**Newfoundland and Labrador Hydro
Demand and Energy Requirements
Forecast 2001 – 2010¹
Total Island Interconnected System²**

<u>Year</u>	<u>MW</u>	<u>GWh</u>
2000 Actual	1443	8057
2001	1576	8240
2002	1602	8316
2003	1611	8384
2004	1632	8479
2005	1652	8560
2006	1673	8639
2007	1696 (Revised)	8734
2008	1719	8831
2009	1735	8894
2010	1741	8929

¹ Source: Long-Term Planning Load Forecast 2001.

² Includes load requirements met by Hydro's sources and customers' generation facilities.