

- 1 Q. With respect to Budgell's evidence page 12, lines 1-13 on the Wind
2 Demonstration Project:
- 3 1. What are the actual/estimated cost for each year of the demonstration
4 project?
- 5 2. Is this cost being passed on to Hydro's customers?
- 6 3. What is the average cost in cents per kwh for Wind generation in other
7 places where it is used?
8
9
- 10 A. 1. Please refer to Hydro's response to PUB 1.1. These estimates are to
11 be determined by the feasibility study, which won't be completed until
12 June 2002.
13
- 14 2. There are no costs for the project at this time, however should the
15 project proceed, Hydro will seek approval for the costs to be included
16 in rates.
17
- 18 3. Hydro does not have specific information on wind generation costs in
19 other places. However, a Natural Resources Canada publication
20 indicates, "*generators cost about \$1500 per kilowatt for wind farms
21 that use multiple-unit arrays of large machines. Smaller individual
22 units cost up to \$3000 per kilowatt. In good wind areas, the costs of
23 generating electricity range between five and ten cents per kilowatt
24 hour.*" The cost of a project depends on the consideration of many
25 factors such as average annual wind speed, proximity to the utility
26 grid, climatic conditions and site accessibility.

- 1 Q. With regard to Brickhill's evidence page 7, lines 1 - 4, list all the changes in
2 assignment on the Island Interconnected System and the cost impact that
3 each change has on the three customer classes.
4
5
- 6 A. The changes in plant assignment and cost impacts are attached.

**NEWFOUNDLAND AND LABRADOR HYDRO
2002 Forecast Cost of Service
Proposed Changes in Plant Assignment - Cost Impacts (\$000)**

	<u>Before Deficit & Revenue Credit Allocation</u>			<u>After Deficit & Revenue Credit Allocation</u>		
	NP	Industrial	Rural Island Interconnected	NP	Industrial	Rural Island Interconnected
Doyles / Bottom Brook re-assigned from NP to Common	(146)	94	52	(110)	94	---
GNP Transmission assets re-assigned from Rural to Common	7,661	1,387	(8,751)	18	1,386	---
Frequency Converters re-assigned from Common to Specific	(130)	141	(11)	(140)	141	---
S'ville / Bottom Brook assets re-assigned from Common to NP	6	(4)	(2)	5	(4)	---

- 1 Q. With regard to Brickhill's evidence page 8, lines 24 B 29 and schedule II:
- 2 1. Provide data to show the variation over time.
- 3 2. What was the rationale for using years 1994, 1996, 1997, 1998, 1999
- 4 & 2000 in schedule II?
- 5 3. Why was 1995 omitted?
- 6 4. Provide the 1CP, 2CP, 3CP and 4CP allocators for the three customer
- 7 classes for each year 1992 to 2000 inclusive.
- 8
- 9 A. 1. See attached.
- 10
- 11 2. The years were selected to review the data since the Board's Order
- 12 (1993).
- 13
- 14 3. 1995 data was not immediately available in the required format when
- 15 the analysis was prepared. Since the analysis was intended to
- 16 provide only an indication of the variation in base data, no further
- 17 effort was expended. Schedule II has been reproduced, with 1995
- 18 included, in the attached page 4.
- 19
- 20 4. System Peak data prior to 1994 was not reported in a manner
- 21 designed to capture the data provided in 1994 and subsequent years,
- 22 after Hydro received approval from the Board for a change in
- 23 methodology. The effort required to produce the data consistent with
- 24 that methodology is not considered necessary for the matters currently
- 25 before the Board.
- 26
- 27 Multiple CP kW for 1994-2002, at the transmission level, are attached
- 28 as page 5. Transmission level kW do not include allocated losses

1 between generation and transmission, as do the CP kW used in the
2 Test Year Cost of Service to allocate production demand costs.
3 Please see IC-142 for generation level class CPs for 1999-2000.
4 Historic models are not equipped to provide multiple CP allocators at
5 generation. On a percentage per customer basis, the results should
6 not vary significantly after losses are allocated to derive the CP at
7 generation number.

- 1 Q. With regard to Hamilton's evidence page 16, lines 7 - 8:
- 2 1. Does the Interconnected Rural Customer class pay for the 138/25 kV
- 3 transformer losses at Bottom Waters?
- 4 2. If so, how do these losses get incorporated into the rural rate?
- 5
- 6
- 7 A. 1. The 138/25 kV transformer losses at Bottom Waters are allocated to
- 8 the Interconnected Rural Customer class.
- 9 2. Hydro doesn't design rates for the Interconnected Rural Customer
- 10 class. The rates for this group of customers are the same as those
- 11 charged by Newfoundland Power.

1 Q. With respect to the Roddickton, Hawkes Bay and St. Anthony diesel units,
2 has the classification of any of them changed since 1992? If so, which ones,
3 when, on what basis and to what classification.

4

5

6 A. In 1992, these three diesel plants were classified 100% demand-related.
7 The same treatment has been accorded diesel generation in the 2002
8 Forecast Cost of Service.

1 Q. With respect to the diesel units at St. Anthony, Roddickton, and Hawkes Bay:

2

3 1. When did each become part of the Island Interconnected system?

4

5 2. Provide a chart showing the number of times each unit has been used
6 in each year since it became interconnected, the reason it was used
7 on each occasion and the class of customers in need of emergency or
8 peaking capacity on each occasion.

9

10 3. Provide the number of kWh generated by each unit in each year since
11 it was interconnected, the amount of fuel consumed by that unit in that
12 year, the cost of the fuel consumed in that year, the capital costs
13 incurred in relation to that unit in that year and the operating and
14 maintenance costs associated with that unit in that year.

15

16

17 A. 1. The table below shows when the generating plants in question
18 became a part of the Island Interconnected System.

19

Generation Source	Available to Island Interconnected System
St. Anthony Diesel Plant	September 7, 1996
Roddickton Diesels	September 7, 1996
Hawke's Bay Diesels	June, 1971

20

21

22 2. Records back to 1971 for Hawke's Bay are not readily available thus
23 data since 1992 are used to answer this question. The table shows

1 the number of times during 1992 through 2000 when each of the
2 plants were operated. Operation for testing is excluded from the
3 table.

4

Year	St. Anthony Diesel	Roddickton Diesel	Hawke's Bay Diesel
1992			12
1993			12
1994			9
1995			18
1996	15	5	15
1997	12	5	2
1998	11	9	5
1999	20	2	6
2000	6	0	1

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

The Hawke's Bay diesels have been used to maintain acceptable voltages to Hydro rural customers during scheduled or forced outages on the Great Northern Peninsula. Prior to the construction of additional lines (1990) on the Great Northern Peninsula, Hawke's Bay diesels were used regularly to maintain acceptable voltage to Hydro rural customers with all available transmission in-service. As well, it was used to supply generation requirements for the entire system on January 2, 1996. It helped meet the peak of 1303 MW on that day. Hawke's Bay diesels were also on for system support prior to 1992. One known case identified from a record peak report is February 3, 1990. On that day it was on to meet a system peak of 1316 MW. On both of these occasions Hawke's Bay diesel served all customer classes.

1 On all occasions since the interconnection of St. Anthony and
2 Roddickton, the Roddickton and St. Anthony diesel plants were used
3 to supply Hydro rural customers during forced and scheduled
4 transmission outages on the Great Northern Peninsula.

5

6 3. The table below provides the number of kWh generated by each unit,
7 the amount of fuel consumed by that unit, the cost of the fuel
8 consumed, operating and maintenance costs and capital costs for
9 each year from 1992 to 2000.

Hawkes Bay Diesel

	Energy Produced (Gross kWh)	Fuel Consumed (gallons)	Fuel Cost	O&M Cost	Capital Cost
1992	192,000	12,915	\$12,811	\$92,622	\$0.00
1993	168,000	11,531	\$11,070	\$103,796	\$0.00
1994	115,200	8,464	\$8,061	\$91,940	\$0.00
1995	600,000	38,386	\$47,656	\$97,938	\$0.00
1996	600,000	39,011	\$51,750	\$136,628	\$0.00
1997	129,600	9,672	\$12,546	\$28,283	\$0.00
1998	115,888	8,092	\$8,915	\$69,624	\$0.00
1999	170,056	11,492	\$14,019	\$67,358	\$0.00
2000	51,100	4,947	\$7,088	\$76,971	\$0.00

St. Anthony Diesel

	Energy Produced (Gross kWh)	Fuel Consumed (gallons)	Fuel Cost	O&M Cost	Capital Cost
1992					
1993					
1994					
1995					
1996	1,051,700	110,272	\$132,941	\$544,453	\$0
1997	257,398	19,136	\$23,726	\$141,863	\$0
1998	395,200	30,300	\$28,773	\$97,466	\$0
1999	216,000	17,136	\$17,041	\$129,804	\$0
2000	139,200	8,596	\$11,524	\$177,040	\$0

Roddickton Diesel

	Energy Produced (Gross kWh)	Fuel Consumed (gallons)	Fuel Cost	O&M Cost	Capital Cost
1992					
1993					
1994					
1995					
1996	180,960	12,939	\$15,853	\$59,080	\$0
1997	66,000	5,266	\$6,963	\$19,549	\$0
1998	122,400	8,050	\$10,022	\$41,445	\$0
1999	19,800	875	\$969	\$9,338	\$0
2000	0	0	\$0	\$10,086	\$0

1 Q. How have runner replacements on Bay d'Espoir units 1 - 6 improved:

2 1. reliability?

3 2. efficiency?

4 3. environmental performance?

5

6

7 A. 1. Reliability

8

9 Prior to the replacement of the runners frequent problems that
10 occurred that affected the reliability of the units included:

11

12 a) Galvanic corrosion/cavitation of the runner components.

13

14 b) Failure of the bolts securing the stationary primary
15 wearing rings in the headcover and discharge ring.

16

17 c) Cracking of the runner blades.

18

19 Since the replacement of the runners all these problems have been
20 eliminated and to date there has been no need for any runner repairs.

21

22 2. Efficiency

23

24 As outlined in the evidence of R. J. Henderson, page 4 lines 10 to 16,
25 there has been a 2.8% increase in unit efficiency.

26

1 3. Environmental Performance

2

3

The runner replacements were undertaken primarily for reliability and efficiency improvements. However, some environmental benefits have been noted.

6

7

a) The change in efficiency and increase in production will result in less production at Holyrood and thereby reduce emissions from that plant.

8

9

10

11

b) During replacement of the runners the main wicket gate bushings were replaced with self lubricating type bushings eliminating the possibility of grease being released to the environment.

12

13

14

1 Q. With respect to the runner replacements on Bay d'Espoir units 1 - 6:

2

3 1. Have the replacements resulted in increased production? If so, to
4 what extent?

5

6 2. Have the replacements resulted in cost savings? If so, in what areas
7 and what savings each year are attributable to that work?

8

9

10 A. 1. Yes, there has been an increase in production as outlined in the
11 evidence of R. J. Henderson, page 4 lines 1 to 16.

12

13 2. Yes, there have been savings in the areas of cavitation and corrosion
14 repairs, blade crack repairs and in the dismantling and reassembly of
15 the units to make major repairs. The annual savings for all units is
16 estimated to be \$100,000.

- 1 Q. How have the exciter replacements on Bay d’Espoir units 1 - 6 improved:
2 1. reliability?
3 2. efficiency?
4 3. environmental performance?

5
6

- 7 A. 1. Reliability

8

9 Items incorporated into the design for the new ABB exciters to
10 improve reliability are redundant bridges, redundant ac/dc power
11 supplies, individual field flashing circuits as opposed to one source for
12 all exciters and monitoring functions in the software itself.

13

14 The following statistics are presented to identify the fact that there
15 may have been some problems with the new exciters. However, the
16 majority of the problems with the new exciters have been minor in
17 nature and easier to troubleshoot resulting in reduced outage
18 durations.

19

20 The forced outage rate for the new ABB exciters (1997 to present) is
21 2.22 forced outages/year where as the old GE exciters had a trip rate
22 of 1.74 trips/year (For the period 1967 to 1993). However, the
23 average outage duration for the new ABB exciters is 10.5 hours/year
24 as opposed to 32.95 hours/year for the old GE exciters (for the period
25 1983 to 1993). In addition, the ABB statistics include all forced
26 outages as opposed to just trips when the units are in service.

27

1 2. Efficiency

2

3 The ABB exciters installed on Bay d'Espoir Units 1-6 have not had an
4 effect on plant efficiency.

5

6 3. Environmental Performance

7

8 The GE exciters had PCB capacitors which have now been removed.

1 Q. With respect to the exciter replacements on Bay d'Espoir units 1 - 6:

2

3 1. Have the replacements resulted in increased production? If so, to
4 what extent?

5

6 2. Have the replacements resulted in cost savings? If so, in what areas
7 and what savings each year are attributable to that work?

8

9

10 A. 1. There has been no increase in production.

11

12 2. The cost savings associated with the new exciters are realized in the
13 reduction in outage time (reduced overtime) and reduced maintenance
14 costs. In 1988/89 \$55,000 was spent on the old GE field breakers and
15 in 1990/91 \$110,000 was spent on the old GE power supplies.

1 Q. How have each of (a) the exciter replacements on Holyrood units 1 and 2;
2 (b) the Electro-Hydraulic Control (EHC) replacement on Holyrood unit 2; (c)
3 the installation of on-line performance monitoring at Holyrood; (d) the Boiler
4 Control and Station Service Control replacement on Holyrood unit 3; (e) the
5 new water treatment plant at Holyrood and (f) the upgrade of the wastewater
6 facility and other environmental improvements at Holyrood improved:

7

8 1. reliability?

9 2. efficiency?

10 3. environmental performance?

11

12

13 A. (a) Holyrood Units 1 and 2 exciter replacements;

14

15 1. Reliability

16

17 The exciter replacement project was undertaken as a result of
18 equipment obsolescence in that GE no longer supported the
19 electronic cards. Also some of the components on these cards
20 were no longer available. There are no statistics indicating
21 reliability performance before and after installation. However,
22 continued operation with obsolete parts would have led to
23 reliability problems similar to Bay d'Espoir as these exciters
24 were of similar design and vintage.

25

26 2. Efficiency

27

28 There were no efficiency implications from this project.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29

3. Environmental Performance

The GE exciter had PCB capacitors which have now been removed.

(b) Holyrood Unit 2 Electro-Hydraulic Control Replacement;

1. Reliability

This project was undertaken as a result of equipment obsolescence in that GE no longer supported the electronic cards.

This project also gave the plant an ability to black start the generator to a dead bus and give frequency control as it is loaded, both of which can provide reliability benefits to customers on the system.

2. Efficiency

There are no efficiency improvements from this project.

3. Environmental Performance

There are no environmental performance improvements from this project.

1 (c) Holyrood On-Line Performance Monitoring;

2

3 1. Reliability

4

5 This project did not have a reliability impact.

6

7 2. Efficiency

8

9 This project was undertaken to improve the efficiency of the
10 Holyrood station. It provides continuous real time data to the
11 operator. This allows the operator to configure the unit at the
12 lowest cost possible and therefore optimum efficiency.

13

14 3. Environmental Performance

15

16 This project also improves the environmental performance in
17 that any gains in efficiency will mean less fuel consumed and
18 less emissions.

19

20 (d) Holyrood Boiler Control and Station Service Control Replacement;

21

22 1. Reliability

23

24 This project was undertaken as a result of equipment
25 obsolescence in that spare parts were no longer available to
26 maintain the equipment.

27

1 2. Efficiency

2

3 There are no efficiency improvements from this project.

4

5 3. Environmental Performance

6

7 There are no environmental performance improvements from
8 this project.

9

10 (e) Holyrood New Water Treatment Plant;

11

12 1. Reliability

13

14 This project was undertaken to replace deteriorated equipment
15 that had reached the end of its useful life.

16

17 2. Efficiency

18

19 The new plant generates high purity water more efficiently.

20

21 3. Environmental Performance

22

23 It has improved in environmental performance. Generating
24 high purity water is a chemical process that involves raw
25 materials, caustic soda and sulfuric acid to mention a few.
26 Generating water more efficiently means less raw material
27 present in the output. This results in less waste chemical on an
28 annual basis.

29

1 (f) Holyrood – Upgrade of Wastewater Facility;

2

3 1. Reliability

4

5 There are no reliability improvements from this project.

6

7 2. Efficiency

8

9 There are no efficiency improvements from this project.

10

11 3. Environmental Performance

12

13 Industrial wastes generated at the Holyrood plant prior to 1996
14 were disposed of at Robin Hood Bay Municipal landfill.

15 Development of this site meant all industrial waste would be
16 contained in a secure landfill at the Holyrood site.

1 Q. With respect to each of the improvements referred to in the previous
2 question:

3

4 1. Have the improvements resulted in increased production? If so, to
5 what extent?

6 2. Have the improvements resulted in cost savings? If so, in what areas
7 and what savings each year are attributable to each improvement?

8

9

10 A. 1. The following improvements resulted in increased production:

11

12 Performance Monitoring - auxiliary power consumption has been
13 reduced meaning more energy is available for customers as opposed
14 to being used internally within the plant.

15

16 2. The following improvements resulted in cost savings:

17

18 Water Treatment Plant – the new water treatment plant has resulted in
19 cost savings resulting from less chemical consumption, lower overtime
20 requirements and less wear and tear on the equipment. There have
21 been no formal computations of the actual cost savings.

22

23 Performance Monitoring - The performance monitoring has increased
24 efficiency, which has resulted in reduced fuel consumption and lower
25 fuel costs. This along with the reduced auxiliary power consumption
26 has resulted in the increase of the Holyrood conversion factor from an
27 average of 605 kWh/bbl to 610 kWh/bbl.

1 Q. What are the “other environmental improvements at Holyrood”? What was
2 the cost of each and why was it done?

3

4

5 A. The “other environmental improvements at Holyrood” refers to the following:

6

7 (a) Ambient Air Monitoring Program – Hydro in 1995 enhanced its
8 program of monitoring the ambient concentration of Sulphur Dioxide
9 (SO₂) and Particulate Matter. In 1997 Hydro installed a
10 meteorological station near the plant in order to do dispersion
11 modeling of emissions and to assist in identifying future operating
12 problems. This was done as part of regulatory requirements for plant
13 operation. The total purchased and installation cost of the equipment
14 is approximately \$354,000. The annual operating cost is
15 approximately \$73,000.

16

17 (b) Controlled Waste Landfill – In 1999 Hydro initiated the building and
18 operation of a controlled waste landfill. This was done for the reasons
19 outlined on 14 to 18 on page 5 of R. J. Henderson’s evidence. It cost
20 approximately \$976,000 to develop this facility. It cost \$60,000 in
21 2000 to operate.

22

23 (c) Creation of a Community Liaison Committee – In 1998 this committee
24 was formed with members from the town councils of Conception Bay
25 South and Holyrood, the Provincial Department of Environment and
26 Lands, the Regional Community Health Board, the IBEW union and
27 Holyrood generating Station management. This was initiated to have

1 better communications between Hydro and the stakeholders in its
2 environmental performance. The estimated annual cost is \$5,000.

3

4 (d) ISO 14001 Environmental Management System – In 1998 an
5 Environmental Management System (EMS) conforming to the ISO
6 14001 standard was developed. The reasons in addition to those
7 outlined on page 21, lines 12 to 28 of W. E. Wells evidence are as
8 follows:

9

- 10 • better control and management of environmental issues;
- 11 • establishment of comprehensive due diligence with respect to
12 environmental aspects;
- 13 • cost effective implementation of environmental management
14 programs which is emphasized and promoted;
- 15 • budgets for remediation, abatement and prevention of
16 environmental aspects are directed towards the areas of
17 greatest concern first;
- 18 • specifically in the case of Holyrood the unit efficiency
19 environmental management program is an environmental
20 initiative that has seen positive improvements in the unit
21 efficiency.

22

23 It is estimated to cost approximately \$290,000 (excluding internal staff
24 time) per year to maintain Hydro's commitment to this system at
25 Holyrood.

1 Q. With respect to page 5, lines 23 - 31 of the evidence of R. J. Henderson:

2

3 1. How many kWh of energy have each of Corner Brook Pulp and Paper
 4 Limited (CBPPL) and Abitibi Consolidated Inc. (ACI) supplied to Hydro
 5 in each of the years 1992 - 2000 inclusive?

6

7 2. How much did Hydro pay each of CBPPL and ACI for energy supplied
 8 in each of the years 1992 - 2000 inclusive for energy surplus to their
 9 needs?

10

11 3. What is the basis upon which Hydro paid for surplus energy from
 12 CBPPL and ACI each of 1992 - 2000?

13

14 4. What is the dollar value of the surplus energy supplied by each of
 15 CBPPL and ACI in the years 1992 - 2000 for which they were not paid
 16 any compensation?

17

18

19 A. 1. Please refer to the following table:

20

Year	CBP&P (Deer Lake Power)		ACI (Grand Falls)	
	kWh	Cost	kWh	Cost
1992	987,806	\$20,305	3,297,411	\$32,178
1993	3,198,476	\$42,588	3,217,764	\$7,573
1994	798,656	\$18,168	1,468,994	\$13,761
1995	1,112,604	\$19,963	567,495	\$3,660
1996	737,493	\$17,282	9,602,557	\$140,498
1997	659,974	\$16,386	5,437,879	\$80,276
1998	1,708,875	\$17,161	168,918,161	\$0
1999	453,739	\$13,098	0	\$0
2000	128,144	\$3,305	171,653	\$2,760

1 2. Please refer to the above table.

2

3 3. Hydro paid for the surplus energy in accordance with the agreements
4 referenced in IC-43. In relation to the agreement with Corner Brook
5 Pulp and Paper the rate paid is as established by PUB order P.U. 24
6 (1988).

7

8 4. There was surplus energy supplied to Hydro by Corner Brook Pulp
9 and Paper and ACI (Grand Falls) in 1998, which was also surplus to
10 Hydro's requirements. Hydro took receipt of the energy without
11 paying for it as Hydro's reservoirs were near full at the time and at risk
12 of spilling. The energy was taken by Hydro on the condition that if it
13 caused Hydro to spill later it would not be paid for. In September 1998
14 and from March to June 1999 Hydro spilled water due to high inflows
15 and high reservoirs levels at the end of 1998 caused by low load
16 during the ACI strike at Grand Falls and Stephenville in 1998. Hydro
17 spilled the energy equivalent of water in excess of the 169.9 GWh
18 delivered to Hydro by these customers. Therefore there was no value
19 to this energy.

1 Q. With respect to “lowest historic inflow sequence experienced”, what was that
2 assumption in the forecast for each of the years 1990 - 2000, the number of
3 years data utilized to support that forecast and the actual experience in that
4 year?

5

6

7 A. In all years the hydroelectric production forecast was the then current annual
8 average energy capability which is based on all historic inflow sequences
9 including the lowest sequence. Hydro’s actual experience in inflows for each
10 year since 1990 are provided in the answer to IC-155. These years
11 experienced significantly higher inflows than the lowest historic inflow
12 sequence.

1 Q. Identify the dates and nature of any interconnections to the Hydro Rural
2 system in the period 1992 – 2000 and the operating load impacts for Hydro
3 Rural of those connections for 1992 – 2000.

4
5

6 A. There were six systems interconnected to the Hydro rural system in the
7 period 1992 – 2000.

8

9 The Petite Forte system was interconnected to the Island Interconnected
10 System in September 1993. This utilized 18 km of 14.4 kV single phase
11 overhead distribution line, originating at Newfoundland Power’s Brookside
12 Substation.

13

14 The St. Anthony-Roddickton system was interconnected to the Island
15 Interconnected system in September 1996. This required the construction of
16 103.8 km of 138 kV transmission line, 47.8 km of 69 kV transmission line,
17 conversion of 86.8 km of 66 kV transmission line to 138 kV operation,
18 conversion of the existing 66/12.5 kV terminal stations at Plum Point and
19 Bear Cove to 138/12.5 kV stations, construction of a 138/69 kV station at St.
20 Anthony Airport and construction of a 69/25 kV terminal station at St.
21 Anthony Diesel Plant.

22

23 The Westport system was interconnected to the Island Interconnected
24 system in October 1996. This utilized 40.5 km of 14.4 kV single phase
25 overhead distribution line originating at Newfoundland Power’s Seal Cove
26 Road Substation.

1 The South East Bight system was interconnected to the Island
2 Interconnected system in March 1998. This utilized 24 km of 14.4 kV single
3 phase overhead distribution line originating at Monkstown.

4
5 The Mud Lake system was interconnected to the Labrador Interconnected
6 system in November 1998. This utilized 9 km of 14.4 kV single phase
7 overhead distribution line and a 1.5 km submarine cable originating at Happy
8 Valley.

9
10 The Lapoile system was interconnected to the Island Interconnected system
11 in December 1999. This utilized 11 km of 14.4 kV single phase overhead
12 distribution line and a 3.7 km submarine cable originating at Grand Bruit.

13
14 For operating load impacts for Hydro Rural of these connections for 1992 –
15 2000, please see attached table.

Date of Interconnection		Annual Energy Sales (at Bulk Delivery Point) and Peak Demand															
		1993		1994		1995		1996		1997		1998		1999		2000	
		MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW
1993	Petite Forte	149	137	474	150	492	172	485	171	486	182	484	184	485	172	502	173
1996	Roddickton/St. Anthony ¹							15350	9692	45939	10160	47720	10872	50214	11636	53052	11069
1996	Westport							288	424	1527	432	1553	432	1583	396	1626	468
1998	South East Bight ²											383	145	554	N/A	564	N/A
1999	La Poile ²													576	N/A	613	N/A
	Total	149	137	474	150	492	172	16123	10287	47952	10774	50140	11633	53412	12204	56357	11710
1998	Mud Lake ³													N/A	N/A	N/A	N/A

3. Mud Lake is not metered separately from Happy Valley

1 Q. Provide the same information with respect to the Doyles-Port aux Basques
2 system re-assignments?

3

4

5 A. The cost implications are as follows:

6

7 Newfoundland Power \$110,000 decrease

8 Island Industrial Customers \$94,000 increase

9

10 Note that these numbers do not incorporate any changes to revenues, or any
11 related impacts associated with interest and return on rate base, from those
12 filed in Exhibit JAB-1.

1 Q. Further to Schedule XIV on the Rate Stabilization Plan (RSP) provided by J.
2 C. Roberts, provide a set of Tables with supporting schedules and notes as
3 required to indicate the following for each year's actual results by month from
4 1992 to 2000 and for each year's forecast results by month for 2001 and
5 2002:

6

7 1. Opening Balance of RSP, showing the total and the sub-amounts for
8 Newfoundland Power (NP) and Island Industrial Customers (IC);

9

10 2. The adjustments made in that month and year for each RSP component
11 (e.g., hydraulic production variations, fuel component of load variations,
12 revenue component of load variations, fuel cost variations, rural rate
13 alterations); fully explain the basis for each adjustment, and provide the
14 specific Test Year Cost of Service Study forecasts used to calculate any
15 variance;

16

17 3. The monthly customer allocation (among NP, IC, Rural Island
18 Interconnected, and Labrador Interconnected) for each RSP component;
19 fully explain the basis for each allocation; indicate any allocations to Rural
20 Island Interconnected and Labrador Interconnected that are removed from
21 the RSP and written off against Hydro's net income (loss);

22

23 4. The year-end adjustment made to recover or pay out one-third of the RSP
24 amount owing to or from NP; indicate how this is accounted for and when
25 the amounts are actually recovered;

26

-
- 1 5. The year-end adjustment made to recover or pay out one-third of the RSP
2 amount owing to or from IC; indicate how this is accounted for and when
3 the amounts are actually recovered;
4
- 5 6. Indicate any management fee or administrative charges by Hydro to the
6 RSP; indicate fully the basis for determining any such charges. Indicate
7 how any such fee is accounted for in Hydro's accounts related to its
8 regulated activities;
9
- 10 7. Indicate any financial charges on (or credits to) the RSP; indicate fully the
11 basis for determining any such charges or credits (if a specific Hydro
12 weighted average cost of capital is used, provide this cost for each
13 calculation). Indicate how any such charge or credit is accounted for in
14 Hydro's accounts related to its regulated activities.
15
- 16
- 17 A. 1. Please see response to IC-73 for the years 1992 to 2000 and to PUB-59
18 for 2001 and 2002.
19
- 20 2. Please see response to IC-73 for the years 1992 to 2000 and to PUB-59
21 for 2001 and 2002.
22
- 23 3. Please see response to IC-73 for the years 1992 to 2000 and to PUB-59
24 for 2001 and 2002.
25
- 26 4. Please see response to IC-73 for the years 1992 to 2000 and to PUB-59
27 for 2001 and 2002.
28

- 1 5. Please see response to IC-73 for the years 1992 to 2000 and to PUB-59
- 2 for 2001 and 2002.
- 3
- 4 6. Please see response to IC-13.
- 5
- 6 7. Please see response to No. 1 above for financing charges included in the
- 7 RSP and response to NP-47 for the calculation of the interest rate.

1 Q. Indicate projected costs in U.S. dollars of No. 6 fuel in each of the years 2002
2 - 2011, inclusive, based (a) on the forecasts adopted in the application
3 (consistent with Henderson, Schedule VII), and (b) based on the best and
4 most current information available to Hydro.

5
6

7 A. (a) The forecast market prices for No. 6 fuel based on the September
8 2000 PIRA forecast are as follows:

9

2002	19.88 \$US/bbl
2003	18.23 \$US/bbl
2004	16.38 \$US/bbl
2005	16.58 \$US/bbl

2010 19.66 \$US/bbl

After contract discounts of \$0.11 to
\$0.14 per BBL

10

11

12 (b) The forecast market prices for No. 6 fuel based on the July (short
13 term) and June (long term) 2001 PIRA forecast are as follows:

2002	18.78 \$US/bbl
2003	18.33 \$US/bbl
2004	17.28 \$US/bbl
2005	17.03 \$US/bbl
2010	21.26 \$US/bbl

After contract discounts of \$0.11 to
\$0.14 per BBL

1
2
3
4
5
6
7

Please note PIRA provides a 2010 forecast beyond 2005. Hydro normally does a straight-line interpolation between these dates. For forecasts beyond 2010 Hydro consults with PIRA on long term sustainable crude prices and derives a No. 6 fuel price based on normal spreads between crude and No. 6 fuel.

1 Q. Indicate projected exchange rates used by Hydro to convert No. 6 fuel costs
2 in Canadian dollars in each of the years 2002 - 2011, inclusive.

3

4

5 A. The projected exchange rates used during the preparation of the Fall 2000
6 fuel price forecast are as follows:

7

2001	0.694 \$US/\$1CAN
2002	0.701
2003	0.701
2004	0.708
2005	0.713
2010	0.727

8

1 Q. Indicate how much of the actual fuel costs for No. 6 fuel consumed in each
2 year from 1992 - 2001 inclusive was charged to the RSP, how much of such
3 charges to the RSP were passed through to NP and IC respectively, and
4 what impact such RSP pass through had on average rates charged to NP
5 and IC respectively.

6

7

8 A. Please see responses to IC-73 and PUB-59. Schedules showing the RSP
9 impact on rates is attached.

1 Q. Indicate the projected No.6 fuel charges to the RSP for each of the years
2 2002 to 2111 inclusive, as well as any other currently projected charges to
3 the RSP, the amounts of such charges projected to be passed on to NP and
4 IC respectively in each year, and what impact such RSP pass through is
5 projected to have (based on the assumptions and forecasts in Hydro's
6 application) on average firm rates charged in each year to NP and IC
7 respectively.

8

9

10 A. Projections are not available past the year 2005. Please see response to
11 PUB-59 for 2002. The RSP reports for 2003 to 2005 are attached and during
12 this period it is assumed for the purpose of these calculations that there is no
13 change in base rates or the price of No. 6 fuel included in the base rate.
14 Please see IC-191 for schedule showing impact of RSP on rates.

1 Q. R. Henderson's Testimony

2 1. With reference to Schedule 1, what is the firm energy capability of
3 each of the plants?

4 2. Indicate the basis for firm energy determinations for each hydroelectric
5 plant (including each NUG), and the overall probability distribution for
6 the range of hydraulic generation that Hydro could experience based
7 on available information. Indicate the extent to which firm hydraulic
8 generation estimates have changed since 1992.

9 3. For reliability purposes, what firm energy estimates are used for
10 combustion turbine and diesel generation plants in Schedule 1?

11 4. Reference page 5, lines 24 and 25, what are the "long standing
12 arrangements to buy energy"?

13

14

15 A. 1. Please refer to Schedule IX of H. G. Budgell's testimony for the firm
16 annual energy capability of each of Hydro's generating plants.

17

18 2. Firm energy for hydroelectric plants can be determined in different
19 manners. It is generally the annual production which the facility can
20 maintain under the most onerous hydrological conditions as
21 determined by simulations. For the Bay d'Espoir system which
22 includes the Upper Salmon plant the firm energy is determined by
23 means of simulation of the operation of the plants in the system using
24 a computer model. In the model the load is increased on the system
25 to the point where it is no longer able to meet the load under the
26 lowest inflow conditions. The maximum annual energy that the
27 system can meet as a result of this exercise represents the simulated
28 firm energy. The firm energy from Cat Arm and Hinds Lake were

1 taken from the results of similar simulations done for the feasibility
2 studies for those projects. The firm energy from the NUG's was that
3 amount provided in their project proposal.

4
5 Firm energy estimates are revised from time to time to reflect the
6 impact of operating experience on conversion factors versus those
7 used in the simulation. As well, application of the "definition of firm"
8 may impact on firm energy capabilities.

9
10 The table below shows the annual firm energy estimates by plant for
11 the period 1992-2000 inclusive. Of note, Upper Salmon's firm energy
12 capability changed from 420 GWh in 1996 to 474 GWh in 1997. This
13 is primarily due to a change in the firm definition. The new figure was
14 based on the same firm water cycle used for Bay d'Espoir.

Annual Firm Energy Capability by Plant (GWh)


Year	Bay D'Espoir	Upper Salmon	Hinds Lake	Cat Arm	Paradise River	NLH Mini-Hydro's*	NUGs	Total Firm
1992	2211	418	287	617	26	5	N/A	3564
1993	2211	418	287	617	26	5	N/A	3564
1994	2211	418	287	617	26	5	N/A	3564
1995	2211	418	287	617	26	5	N/A	3564
1996	2216	420	286	613	27	5	N/A	3567
1997	2226	474	286	613	27	5	N/A	3631
1998	2234	476	283	605	27	5	N/A	3630
1999	2234	476	283	605	27	5	107	3737
2000	2234	476	283	605	27	5	107	3737

17 * Snook's Arm, Venam's Bight, and Roddickton Mini-Hydro.

18
19 The graph below shows the distribution of inflows (converted to an
20 energy value) for Hydro's 50 years of hydrological records for all of
21 Hydro's large plants, Bay d'Espoir, Upper Salmon, Hinds Lake and

1
2
3

Cat Arm. This does not give the hydraulic production but is representative of the variation in production.



4
5
6
7
8

- 3. Hydro forecasts no firm energy capability for its combustion turbine and diesel generation plants.
- 4. Please refer to the response to IC-43.

1 Q. How is billing demand to be determined for non-firm energy (Schedule C
2 indicates the maximum Interruptible Demand for any month)?

3

4

5 A. There are two categories of non-firm power and energy, Interruptible Power
6 and Energy and Generation Outage Power and Energy.

7

8 The Interruptible Demand billing is based on the Maximum Interruptible
9 Demand measured in the month as described in the Interpretation and
10 Interruptible Demand articles to the contracts in Schedule C.

11

12 The Generation Outage Demand billing is based on the Maximum
13 Generation Outage Demand measured in the month and pro-rated by the
14 number of days in the month the customer took the Generation Outage
15 Power and Energy. The Generation Outage Demand billing is described in
16 the Generation Outage Power article in the contracts in Schedule C. Please
17 refer to Article 5, Clause 5.01 (d) for Abitibi Consolidated Inc. Grand Falls
18 Division and for Corner Brook Pulp and Paper (Pages 25 and 44 of Schedule
19 C.)

1 Q. Q. K.C. McShane (paged 23-24) indicates two reasons for differences
2 regarding Hydro's capital structure as reported in 1999 and the forecast
3 capital structure for the test year 2002. Provide adjusted debt/equity and
4 interest coverages estimates for Hydro's regulated "utility only" operations for
5 each of the years 1992 to 2001 inclusive (indicating each of the components
6 required for the calculation) on a basis consistent with the assumptions
7 adopted for the 2002 test year but based on actual dividends (if any) paid in
8 each year.

9

10

11 A. The attached schedule shows the calculation of Hydro's regulated "utility
12 only" debt/equity ratios which includes IOC.

13

14 Please refer to the response to NP-2 for the applicable regulated interest
15 coverage ratios.

1 Q. Schedule VIII of the evidence of H.G. Budgell indicates different loads than
2 Schedule V (see 2001 and 2002). Confirm that these differences reflect the
3 inclusion in Schedule VIII of loads met by customers' generation sources.
4 Revise Schedules X to indicate load forecast excluding load met by
5 customers' generation sources.
6

7 A. The loads presented in the direct evidence of H.G. Budgell Schedules V and
8 VIII are different since Schedule VIII loads are for the Total Island
9 Interconnected System, inclusive of load supplied by customers' own
10 generation. Schedule V, by contrast, represents just Hydro's own supply
11 requirements for the Island Interconnected System. The load forecasts
12 contained in Schedules V and VIII are built up from differing methodologies,
13 notably for non-industrial loads, and some underlying differences would be
14 expected.

15
16 Please see attached table for revised Schedule X with the load met by
17 customers' generation sources removed from the load forecast and also with
18 those sources removed from system capability.

**Newfoundland and Labrador Hydro
Island Interconnected System
Existing Generating Capability
Net of Customer Generation and Customer Serviced Load
Energy Balances and LOLH Indices**

<u>Year</u>	<u>Load Forecast</u>		<u>Existing System</u>			<u>Energy Balance</u>
	<u>Peak</u>	<u>Firm</u>	<u>Net</u>	<u>Firm</u>	<u>LOLH</u>	
	<u>MW</u>	<u>GWh</u>	<u>Capacity</u>	<u>Capability</u>	<u>Hrs/yr</u>	<u>GWh</u>
2001	1,303	6,409	1,559	6,733	2.85	324
2002	1,329	6,557	1,559	6,733	3.96	176
2003	1,338	6,620	1,559	6,733	4.70	113
2004	1,359	6,711	1,559	6,733	5.50	22
2005	1,379	6,792	1,559	6,733	8.48	(59)
2006	1,400	6,871	1,559	6,733	11.14	(138)
2007	1,423	6,966	1,559	6,733	15.04	(233)
2008	1,446	7,063	1,559	6,733	17.52	(330)
2009	1,462	7,126	1,559	6,733	24.37	(393)
2010	1,468	7,161	1,559	6,733	26.44	(428)

1 Q. **Cost of Service Study (COSS) evidence - Exhibit JAB**

2

3 **(1) Industrial revenues:** Explain the basis for (a) the Industrial - Firm
4 revenue credit of \$40,326 in Schedule 1.2, line 4, column 4, and (b) the
5 Industrial - Non Firm Revenues of \$381,121 in Schedule 102, line 5, column
6 2. In each instance, indicate all billing determinants and rates assumed for
7 these estimates.

8

9 **(2) Industrial -Non Firm costs:**

10 (a) Indicate any cost based rationale for the demand charge of \$1.50 per kW
11 proposed for non-firm sales to IC.

12 (b) Confirm that the COSS provides no analysis of any demand related costs
13 for non-firm sales, and that the costs assigned to this service in the COSS
14 are solely the firm energy cost of \$.02311 per kWh. (Schedule 1.3, page 1)

15 (c) Provide a table setting out the assumed COSS generation (MWh) by
16 source (hydraulic, No. 6 fuel, diesel fuel, gas turbine fuel, power purchases
17 from NUGs, power purchases from non-NUGs) and month for the test year
18 2002 for the Island Interconnected System. Indicate the likely percent of load
19 supplied by thermal during off-peak hours (low load evenings and weekend
20 hours) during each month.

21 (d) Indicate annual functionalized cost of service for each of the above
22 generation sources (in (c) above) and for transmission based on COSS for
23 the Island Interconnected System, showing separately for each generation
24 source and for transmission (where this is separate): fuel expenses, O&M,
25 depreciation, expense credits, disposal gain/loss, return on debt and return
26 on equity. Indicate classified generation and transmission costs (Production
27 Demand, Production and Transmission Energy, Transmission Demand)
28 separately for each fuel source and for transmission.

1 (e) Compare in detail the COSS firm energy cost of \$.02311 per kWh and the
2 non-firm energy charge rate as proposed in Schedule A of the Application
3 (page 3), assuming the average cost of fuel assumed for the COSS; indicate
4 how this charge could likely vary by month and time of day, based on the
5 assumptions adopted for COSS as to expected fuel use. Explain how in
6 practice it will be determined what fuel source is used to supply non-firm
7 energy. What will happen if this energy is supplied in whole or in part from
8 non-thermal sources?
9

10 **(3) Holyrood average capacity factor:** Provide, on the same basis as
11 Schedule 4.3, the calculations to indicate the forecast net capacity factor for
12 Holyrood for the year 2002. Explain the factors affecting variances in this
13 capacity factor for the years 1997 through 2002. Assuming that the COSS for
14 2002 assumes No. 6 fuel consumption based on average hydraulic
15 generation availability and forecasts loads, why would it not be more
16 appropriate to use the net capacity factor consistent with these assumptions
17 rather than one based on the prior 5-year actual average?
18

19 **(4) Loads used for COSS:** Provide a table of the Island Interconnected
20 System test year 2002 setting out for each rate class the following
21 projections: billing demands at customer meter; coincident peak loads at
22 customer meter and at generator (after provision for losses); 2CP kW at
23 customer meter and at generator (after provision for losses); sales at
24 customer meter and generation energy requirements after losses; number of
25 customers for COSS allocation purposes. Explain all assumptions used to
26 derive these projections.
27

28 **(5) Load Factor classification - generation costs:** Review the rationale
29 behind the Board's 1993 Report recommendation for splitting hydraulic plant

1 costs for the Island Interconnected System between energy and demand
2 based on the system load factor. Indicate the change that this creates from
3 the previous COSS adopted by Hydro for the last rate hearing. Indicate the
4 rationale for also applying the load factor of each Isolated Diesel system
5 group in order to split diesel plant costs between energy and demand.

6
7 **(6) Generation cost allocation:** As reviewed in the evidence of J. A.
8 Brickhill (page 8), generation costs for the Island Interconnected System
9 have been allocated among rate classes based on a 2CP allocator. Provide
10 the loss of load hours (LOLH) study carried out by Hydro which supports use
11 of a 2CP allocator because it indicates a greater risk of loss of load hours
12 largely in two winter months. Provide the annual data supporting Schedule II
13 of J. A Brickhill's evidence for each year indicated in this schedule (1994,
14 1996, 1997, 1998, 1999, 2000); provide the same information for 1995 (if
15 available), projections for 2001, and the numbers supporting the projections
16 for 2002. Indicate any other tests that could reasonably be considered when
17 testing an allocation method in addition to the variation in results over time,
18 and assess the 2CP method in light of each such test.

19
20 **(7) Changes to rural deficit allocation:** L. A Brickhill indicates at page 14
21 that the method of allocating the rural deficit between customers has
22 changed to reflect the change in methodology from AED-based to CP-based.
23 Indicate the difference in COSS results due to this one change in
24 methodology, and the impact that this change has on allocation of the rural
25 deficit for the 2002 test year.

26
27 **(8) Changes in RSP allocation:** L. A Brickhill indicates at page 15 that the
28 RSP has historically been split between participating customer groups based
29 on Hydro's COSS. Indicate what changes, if any, the current COS

1 methodology makes with respect to such splits compared to the COSS
2 methodology used previously and provide an assessment of the differences if
3 any that result to the test year 2002 RSP allocation as provided for in
4 schedule 1.2.1 of the COSS.

5

6 A. (1)(a) The Industrial - Firm revenue credit of \$40,326 in Schedule 1.2, line 4,
7 column 4, (Exhibit JAB-1, page 4) was allocated to customer classes based
8 on revenue requirement. The \$40,326 was therefore calculated as follows:

9

10	Industrial Firm Revenue Requirement	
11	Before Deficit and Revenue Credit	\$ 50,005,883
12	Divided by:	
13	Total Island Interconnected Revenue	
14	Revenue Requirement (Excluding Non-	
15	Firm Revenue Requirement)	\$277,812,814
16	Equals	18%
17	Multiplied By	
18	Total Island Interconnected Non-Firm	
19	Revenue Credit	\$ 224,033
20	Equals	\$ 40,326

21

22 (1)(b) The Industrial - Non Firm Revenues of \$381,121 in Schedule 1.2, line
23 5, column 2 was calculated as shown on the attached Page 10 of 11.

24

25 (2) Industrial -Non Firm costs:

26 a) Please see response to NP-183.

27

28 b) The costs assigned to non-firm sales are as detailed in the Island
29 Interconnected schedule showing the allocation of functionalized

1 amounts to classes of service (Exhibit JAB-1, pages 39-40). The
2 \$157,088 is comprised of only energy cost allocations. The firm
3 energy cost of \$.02311 per kWh was derived from these allocated
4 costs, rather than providing the basis for determining the costs.

5
6
7
8

c) The table below shows the assumed Cost of Service Generation by source for the test year 2002 for the Island Interconnected System.

**Island Interconnected System
Assumed Cost of Service Generation by Source
(MWh)**

Month	Hydraulic Plants	Holyrood (No.6 Fuel)	Diesel Plants	Gas Turbine Plants	Power Purchase NUGs	Other Power Purchase
January	410,410	304,890	30	1,070	11,600	0
February	368,120	275,390	30	240	9,320	0
March	426,860	228,670	30	220	9,920	0
April	353,830	196,700	30	220	11,120	0
May	331,890	152,450	30	220	13,810	0
June	329,580	98,350	30	220	13,320	0
July	408,050	0	30	220	13,000	0
August	401,530	0	30	220	12,820	0
September	273,460	147,530	30	220	12,360	0
October	290,850	203,260	30	220	13,240	0
November	314,300	245,880	30	220	12,870	0
December	362,790	304,760	30	900	12,520	0
Total	4,271,670	2,157,880	360	4,190	145,900	0

9
10
11
12
13
14

While thermal generation is required to complement production from Hydro's hydraulic resources in order to meet the overall system load, its output is varied to maintain system security and for water management reasons.

1 Normally, thermal generation is base loaded at an efficient output
2 level. Hydraulic generation is used to track the system load. Thermal
3 output may be reduced for system security or for system loading
4 reasons (ie. not enough load to share amongst required on-line
5 generation). As well, thermal output may be increased from its base
6 load to meet system peak requirements.

7

8 Each week, System Operations sets the thermal base load
9 requirement to manage the water resource while respecting power
10 system security. The likely percent of loading supplied by thermal
11 generation during off peak hours varies as a result of the items
12 previously mentioned, however, the likely percent of system load
13 supplied by thermal generation in the off-peak hours is 2 to 5 percent
14 higher than the percent of system load supplied by thermal generation
15 in the on-peak hours.

16

17 d) This analysis is not currently available, but work is in progress.

18

19 e) The following table compares the industrial firm energy charge with
20 the industrial non-firm energy charge by month for 2002. It uses the
21 average cost of fuel used in the cost of service for each source.

Comparison of Industrial Firm Rates and Non-Firm Energy Rates

Month	Firm Energy Rate	Holyrood Non-Firm Energy Rate	Variance from Firm	Gas Turbine Non-Firm Energy Rate	Variance from Firm	Diesel Non-Firm Energy Rate	Variance from Firm
January	\$0.02311	\$0.04387	\$0.02076	\$0.10401	\$0.08090	\$0.10743	\$0.08432
February	\$0.02311	\$0.03914	\$0.01603	\$0.10278	\$0.07967	\$0.10743	\$0.08432
March	\$0.02311	\$0.03914	\$0.01603	\$0.10367	\$0.08056	\$0.10743	\$0.08432
April	\$0.02311	\$0.03745	\$0.01434	\$0.10360	\$0.08049	\$0.10743	\$0.08432
May	\$0.02311	\$0.03745	\$0.01434	\$0.10354	\$0.08043	\$0.10743	\$0.08432
June	\$0.02311	\$0.03686	\$0.01375	\$0.10524	\$0.08213	\$0.10743	\$0.08432
July	\$0.02311	\$0.03686	\$0.01375	\$0.10518	\$0.08207	\$0.10743	\$0.08432
August	\$0.02311	\$0.03686	\$0.01375	\$0.10514	\$0.08203	\$0.10743	\$0.08432
September	\$0.02311	\$0.03657	\$0.01346	\$0.10686	\$0.08375	\$0.10743	\$0.08432
October	\$0.02311	\$0.03639	\$0.01328	\$0.10686	\$0.08375	\$0.10743	\$0.08432
November	\$0.02311	\$0.03620	\$0.01309	\$0.10683	\$0.08372	\$0.10743	\$0.08432
December	\$0.02311	\$0.03613	\$0.01302	\$0.10814	\$0.08503	\$0.10743	\$0.08432

1 The non-firm energy charge will be at the Holyrood non-firm rate for all
 2 periods including the periods when no thermal source is operating,
 3 except when either or both of the diesel plants and the gas turbine
 4 plants are operated or their output must be increased to meet the non-
 5 firm load. Typically the diesel plants or gas turbine plants would be
 6 required to meet non-firm energy requirements during peak load
 7 periods or when there are transmission restrictions to the area of the
 8 grid where the customer is located. Although the higher non-firm rates
 9 could apply during any hour of the year due to transmission or
 10 generation problems, the probability is higher in the winter period
 11 (December to March) and during the peak hours of 0800 to 2000
 12 hours each day.

13
 14 The decision to use a higher cost source is made by the power system
 15 operator when he determines there is insufficient power or energy

1 available from other sources, either hydroelectric or Holyrood to meet
2 the load demanded on the system, or there is insufficient transmission
3 capacity to an area where the non-firm load is being demanded.
4

5 (3) The Holyrood net capacity factor for the year 2002 based on the forecast
6 energy production is as follows:

7

$$8 \quad \frac{2,157,880,000}{466,000 \times 8,760} = 52.86\%$$

10

11 The capacity factors from 1997 to 2000 are based on the thermal production
12 required in those years. Both hydraulic generation and system load affect
13 the Holyrood net production requirement. In all of these years the hydraulic
14 generation was above average resulting in reduced Holyrood requirements.
15 In addition, in 1998 and 1999 net production at Holyrood was reduced further
16 due to the lower load caused by extended labour disputes in the pulp and
17 paper industry. The capacity factors for 2001 and 2002 are based on
18 forecast net production at Holyrood, which is based on the load forecast for
19 those years with average hydraulic production.

20

21 (4) The table requested is shown on the attached page 11 of 11.

22

23 (5) At the last rate hearing, hydraulic plant costs for the Island Interconnected
24 System were split on a 50% demand/50% energy basis in the 1992 COS
25 Study.

26

27 Diesel plants in the Isolated Systems are operated as base load plants
28 similar to the Holyrood Thermal plant. For this application, Hydro has

1 proposed using the system load factor for the Labrador and Island Isolated
2 Systems as a proxy for capacity factor as used for Holyrood for consistency.

3
4 (6) See response to NP-135 for copy of 2CP allocator report. See response
5 to IC-137 regarding data supporting Schedule II of J.A. Brickhill. Other tests
6 which could be reasonably considered are Bonbright's fair-cost-
7 apportionment objective and the consumer rationing objective. The 2CP
8 method meets both. It fairly distributes the generation demand requirement
9 among the Island Interconnected System customers as it reflects cost
10 causality. It promotes the use of economically justified service because it
11 allocates costs to those who cause the incurrence of the costs.

12
13 (7) The 1992 test year Cost of Service (COS) methodology used Average
14 and Excess Demand (AED) kW to allocate production and transmission
15 demand costs to rate classes. The proposed methodology uses Coincident
16 Peak (CP) to perform these allocations. The Cost of Service, revised to
17 reflect the AED methodology, is attached.

18
19 (8) The 1992 test year Cost of Service (COS) methodology used Average
20 and Excess Demand (AED) kW to allocate production and transmission
21 demand costs to rate classes. The proposed methodology uses Coincident
22 Peak (CP) to perform these allocations. This change in methodology
23 impacts the RSP customer splits, as revised actual energy amounts, using
24 AED methodology, also affected demand costs, and revised demands were
25 therefore also required for the RSP split between customer groups.
26 Schedule 1.2.1 (exhibit JAB-1, pages 9-10) is impacted in that CP kW are
27 also used to determine the unit costs of the deficit. It is important to note that
28 cost allocation also would change if AED were used. This analysis does not

1 consider those impacts. The effects of allocating the rural deficit (Schedule
2 1.2.1) using AED on the 2002 forecast annual RSP activity are:

	<u>Proposed</u>	<u>Revised</u>	<u>Difference</u>
5 Newfoundland Power	\$19,380,610	\$19,375,272	\$(5,338)
6 Island Industrial	5,909,874	5,909,874	-
7 Labrador interconnected	<u>199,739</u>	<u>205,077</u>	<u>5,338</u>
8	<u>\$25,490,223</u>	<u>\$25,490,223</u>	<u>-</u>

Interruptible 'A' Rates (Industrial):

	January	February	March	April	May	June	July	August	September	October	November	December	Total
A. Bunker 'C' Consumption (\$/Bbl.)	28.5734	28.4562	28.4562	28.4144	28.4144	28.3998	28.3998	28.3998	28.3925	28.3879	28.3833	28.3816	
B. Efficiency (kWh/Bbl.)	610	610	610	610	610	610	610	610	610	610	610	610	
C. Mill Rate before Administration- (A / B * 1000)	46.84	46.65	46.65	46.58	46.58	46.56	46.56	46.56	46.55	46.54	46.53	46.53	
D. Administration	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
E. Mill Rate (C * (1 + D))	51.52	51.32	51.32	51.24	51.24	51.22	51.22	51.22	51.21	51.19	51.18	51.18	
F. Demand (\$ per kW)	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	
G. Forecast Energy	88,000	82,000	91,000	88,000	85,000	88,000	91,000	91,000	3,237,000	2,681,000	88,000	88,000	
H. Energy Revenue	4,534	4,208	4,670	4,509	4,355	4,507	4,661	4,661	165,767	137,240	4,504	4,504	348,121
I. Forecast Demand	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	6,000	6,000	1,000	1,000	
J. Demand Revenue	1,500	1,500	1,500	1,500	1,500	1,500	1,500	1,500	9,000	9,000	1,500	1,500	33,000
Total Revenue	6,034	5,708	6,170	6,009	5,855	6,007	6,161	6,161	174,767	146,240	6,004	6,004	381,121

**Newfoundland and Labrador Hydro
 2002 Test Year Projections
 Island Interconnected**

	Billing Demands (kW)	CP at Customer Meter (kW)	CP at Generator (kW)	2 CP at Customer Meter (kW)	2 CP at Generation (kW)	Sales at Customer Meter (MWh)	Energy at Generator (MWh)	Number of Customers
1 Newfoundland Power	-	1,026,791	989,280	2,053,582	1,978,568	4,454,800	4,602,195	1
2 Industrial - Firm	2,244,000	172,601	179,125	345,202	358,251	1,464,970	1,513,441	4
3 Industrial - Non-Firm	22,000	-				6,798	7,023	2
Rural								
4 1.1 Domestic	-	24,142	27,814		54,650	107,264	119,486	12,256
5 1.12 Domestic All Electric	-	30,640	35,301		69,359	109,736	122,240	6,783
6 1.3 Special	-	51	59		115	220	245	2
7 2.1 GS 0-10 kW	-	3,223	3,713		7,044	15,763	17,559	1,931
8 2.2 GS 10-100 kW	188,235	9,250	10,657		21,869	54,336	60,527	830
9 2.3 GS 110-1,000 kVa	165,655	5,507	6,308		10,994	39,444	43,802	70
10 2.4 GS Over 1,000 kVa	91,946	5,510	6,256		11,363	31,237	34,524	8
11 4.1 Street and Area Lighting	-	714	823		1,616	3,000	3,342	974
12 Subtotal Rural	445,836	79,037	90,931	-	177,010	361,000	401,725	22,854

Assumptions:

CP at Customer Meter

NP and Industrial CP based on the load forecast January peaks, to which the following Coincidence Factors have been applied:

Newfoundland Power 1.00
 Industrial - Firm 0.92

Rural CP based on load research applied to load forecast.

CP at Generator

Common transmission losses allocated to all rate classes based on transmission level CP.

Distribution losses allocated to rural rate classes only.

Newfoundland Power's CP includes it's own generation, less generation demand credit.

2 CP at Customer Meter

CP at meter for the two peak months of January and December calculated and summed.

Data not available for rural rate classes.

2 CP at Generator

CP at generator for the two peak months of January and December calculated and summed.

Billing Demands, Sales at Customer Meter

Based on load forecast.

Energy at Generator

Common transmission losses allocated to all rate classes based on transmission level energy.

Distribution losses allocated to rural rate classes only.

1 Q. **COSS and Rate Design - Other Issues**

2

3 (1) **No demand charge for NP:** D. W. Osmond's evidence (page 9)
4 indicates that Hydro and NP have reviewed the issue of implementing
5 a demand and energy charge pricing structure and "both companies
6 concur that an energy only rate to Newfoundland Power is still
7 appropriate." Provide a copy of all studies and/or analysis done by
8 Hydro on this matter since 1992. Assess these rate options in light of
9 each of the rate design principles set out at page 2 of P. R. Hamilton's
10 evidence. Indicate the factors that Hydro believes to support an
11 energy only rate for NP as being in the best interests of efficient and
12 fair rates. Based on the 2002 test year COSS, provide a demand and
13 energy rate option for NP for consideration by the Board.

14

15 (2) **Time of Use rates:** Provide any reports or analysis done by Hydro
16 since 1992 to assess time or use rates for Industrial or other customer
17 classes on the Island Interconnected System. Indicate the extent to
18 which Hydro's bulk costs for generation and transmission on this
19 System vary on a time of use basis under normal conditions. Indicate
20 likely peak and off peak periods during each season on this System
21 that might be used for rate purposes, as well as any material
22 variations in seasonal costs that might be considered for such rates.
23 Indicate Hydro's assessment of time-of-use rate implementation within
24 the next five years at least for NP and/or Industrial Customers, and
25 explain fully the basis for this assessment.

26

27 (3) **Deferral of rate design adjustments:** The evidence of D.W. Osmond
28 at pages 12-15 mentions several five-year period rate design

1 adjustments for Isolated Rural System rates which are deferred until
2 the next Rate Application. Explain why these rate design adjustment
3 plans arising from earlier Board reports cannot be placed before the
4 Board today and a plan for implementation set out for review. In
5 particular, explain the rate plan that Hydro is considering to introduce
6 full cost rates for Government agencies and departments (which
7 would require, it is stated, on average increases of 280%) “over a
8 maximum of five years” in light of the current proposal to limit rate
9 increases to these customers at 20% overall.

10
11 (4) **Revenue Cost Coverage Ratios:** P.R. Hamilton comments (at pages
12 3-4) on historic revenue cost coverage (RCC) ratios for different rate
13 classes on the different systems. Indicate the RCC’s for the Industrial
14 Class and NP by year from 1992 to 2002 based on all of Hydro’s
15 available COS studies (prospective and actual) for these years.
16 Indicate in each instance the portion (if any) of the RCC for each of
17 these rate classes affected by Rural Deficit charges.

18
19 (5) **No Rate of Return on Equity charged on Rural Portion:** It is noted
20 that, based on the Board’s past directions, no margin or return on
21 equity has been proposed on Hydro’s Rural Island Interconnected and
22 Isolated Systems assets (see D.W. Osmond, page 7; J. C. Roberts,
23 page 5). Confirm that Hydro has assessed this position in light of the
24 amended legislation that became effective on January 19th 1996 and
25 now requires Hydro to operate as a fully regulated utility under the
26 jurisdiction of the Public Utilities Board, including the provisions
27 therein for a just and reasonable return on rate base.

28

1 (6) **Employee Future Benefits as part of Capital Structure:** Review
2 what conditions and liabilities apply with respect to the mid-year
3 amount for 2002 of \$24.9 million under Liability for Employee Future
4 Benefits. Review the rationale for including this amount as a no-cost
5 capital amount in the capital structure used to finance rate base.

6

7

8 A. (1) Please see response to PUB-68 regarding rationale for energy only
9 rate. During the course of discussions with Newfoundland Power,
10 each party developed various rate structures and adjustment
11 mechanisms. The evaluation of these alternatives reflected the
12 relative situation of each party and the relative priority each placed on
13 Bonbright's rate design objectives. As outlined in the letter from
14 Newfoundland Power, circumstances have changed over the years
15 such that moving to a demand/energy rate structure is no longer
16 necessary or desirable. Hydro agrees with this conclusion and has
17 therefore not proposed a demand energy rate option.

18

19 (2) Hydro has not performed any analysis of time of use rates since 1992
20 and is therefore unable to provide the information requested.

21

22 Hydro filed the attached letter dated June 28, 1985 as part of Hydro's
23 evidence at its 1985 Rate Referral that outlined its views on marginal
24 cost pricing. Hydro does not have any plans at this time to conduct an
25 assessment of time-of-use rates as uncertainties regarding such
26 things as the Lower Churchill development, Island Infeed and cost
27 effectiveness of mandatory time-of-use rates have not changed
28 significantly since this letter was filed.

NEWFOUNDLAND AND LABRADOR HYDRO
Revenue / Cost Coverages
(\$000)

Year	Methodology	Newfoundland Power					Industrial Class				
		Revenues	Costs	Rev / Cost Coverage	Deficit Allocation	Deficit as % of Costs	Revenues	Costs	Rev / Cost Coverage	Deficit Allocation	Deficit as % of Costs
1992 Actual	Interim (92)	195,200	174,395	1.12	22,226	13%	47,096	40,237	1.17	5,128	13%
1993 Actual	Interim (92)	193,133	171,885	1.12	21,118	12%	48,332	42,594	1.13	5,233	12%
1994 Actual	Interim (92)	181,825	159,355	1.14	21,360	13%	37,400	33,812	1.11	4,532	13%
1995 Actual	Interim (92)	203,117	181,240	1.12	22,233	12%	49,240	44,000	1.12	5,398	12%
1999 Actual	Interim (92)	182,517	165,954	1.10	16,546	10%	45,573	41,182	1.11	4,106	10%
1992 Forecast	Interim (92)	194,083	171,839	1.13	22,244	13%	45,547	40,327	1.13	5,220	13%
1992 Forecast	Generic (93)	192,471	169,353	1.14	23,118	14%	43,966	38,685	1.14	5,281	14%
2002 Forecast	Proposed (2001)	213,830	191,058	1.12	22,911	12%	50,357	50,163	1.00	0	0%

1 Q. Provide a version of Schedule IV to the evidence of H.G. Budgell which
2 incorporates the projected 2001 and 2002 data.

3

4

5 A. Schedule IV provides a comparison of the long term forecast filed with the
6 Board in 1991 against the actual load. In 1991, Hydro did not file forecasts
7 for 2001 and 2002. Projections for 2001 and 2002 are provided in Schedule
8 VIII to the Evidence of H.G. Budgell.