

1 Q. For each interruption under the contract with ACI in Stephenville, list the
2 date, duration and the cost to consumers. Does Article 5 of the contract
3 (Schedule C, page 6 of 71) indicate that the maximum Interruptible Demand
4 at ACI Stephenville is 5 MW?

5
6
7
8
9

A. The information requested for each interruption is provided in the following
table:

Interruptible B Interruptions

Event	Date	Duration (hr:min)	Incremental Cost
1	12/16/1993	5:15	\$8,111.06
2	12/30/1993	4:15	\$4,673.94
3	01/17/1994	5:45	\$15,016.02
4	02/09/1994	8:45	\$19,156.70
5	02/13/1994	1:15	\$2,289.18
6	12/10/1994	2:15	\$7,031.09
7	12/11/1994	8:00	\$23,434.39
8	02/14/1995	8:30	\$13,610.45

10
11
12
13
14
15
16
17
18
19
20

Please note that the costs in the table were paid by Hydro and are in addition to the \$1,297,200 paid annually for the right to interrupt. These costs prior to 2002 have not been passed on to consumers.

The maximum Interruptible Demand sold to Abitibi Consolidated Inc. Stephenville is 5 MW. It should be noted that this demand is associated with load taken by Abitibi Consolidated Inc. beyond its firm Power On Order. The amount referred to in the first half of this question is related to Interruptible "B" load which is for firm Power On Order that Hydro has purchased the right to interrupt. The Interruptible "B" load is 46 MW.