

1 Q. (Schedule XI) Provide the cost per kWh associated with production of the
2 three future additions to generation capacity: Granite Canal, ACI Beeton +
3 Bishop's Falls Upgrade; and CBP&P Cogeneration.

4

5

6 A. The levelized cost per kWh for each of the three future additions are shown
7 below:

8

9 Granite Canal: 54.2 mills/kWh

10 ACI Beeton + Bishop's Falls Upgrade: 77.1 mills/kWh

11 CBP&P Cogeneration: 80.0 mills/kWh