

1 Q. In reference to CA 100, wherein Newfoundland Hydro acknowledges
 2 purchases of power from Newfoundland Power, please provide details of
 3 specific purchases for the years 1996 to the present, including the reason for
 4 the purchase and the cost of the purchase in each instance.

5
 6

7 A. Please refer to the following table. Please note that costs are available only
 8 on a monthly basis.

YEAR	DATE	DURATION (Hours)	REASON	COST
1996	02-Jan	3.0	Peak load conditions combined with Upper Salmon unavailable due to frazil ice & Holyrood Unit #2 unavailable due to vibration	\$6,994.43
1996	31-Dec	0.5	Peak load conditions combined with Holyrood Unit #1 unavailable for maintenance	\$1,546.27
1997	08-Dec	1.5	Holyrood Unit #3 unavailable, Units #1 & #2 Tripped, Forced outage on TL 202 while isolating TL 206	\$3,907.11
1998	04-Apr	5.0	Holyrood Units #1 & #2 Tripped	\$11,826.54
1998	17-Apr	0.5	Holyrood Unit #1 Tripped	
1998	29-Apr	1.5	Holyrood Unit #1, only unit online, had to come down due to blown PT fuse	
1998	27-Oct	3.0	TL 202 tripped while TL 206 out	\$2,689.10