

CA 183 In the absence of load research data, how should Hydro go about allocating distribution demand costs on the basis of non-coincident demand?

RESPONSE:

To the extent that available data does not lend itself to the estimation of distribution non-coincident demand, approximate allocators could be developed based on the experience of other utilities, or allocations could be done on the basis of energy consumption until Hydro is able to provide NCP estimates.