

Q. (Re: p.5, lines 1-2)

Provide a table of actual electrical power costs in ¢/kWh for the years 1992 to the present for ACI-Stephenville, ACI-Grand Falls and each of the other ACI mills.

A. The actual costs in ¢/kWh for the years 1992 to the present for ACI-Stephenville and ACI-Grand Falls are in the table below. The ¢/kWh for the ACI mills outside of Newfoundland is confidential commercial information. Furthermore, they are not relevant for the Board's understanding of the application.

Power Cost (¢ / kWh)

<u>Year</u>	<u>ACI-Stephenville</u> (Without Interruptible "B" Rebate)	<u>ACI-Stephenville</u> (With Interruptible "B" Rebate)	<u>ACI-Grand Falls</u>
1992	3.89	3.89	4.76
1993	3.70	3.63	4.32
1994	3.68	3.42	4.09
1995	3.63	3.38	3.98
1996	3.80	3.53	4.21
1997	3.79	3.54	4.80
1998	3.93	3.52	5.61
1999	3.97	3.73	5.56
2000	3.43	3.19	4.75