

1 Q. Supply the data used in calculating the 4% loss as used in the wheeling rate.

2

3

4 A. The 4% losses used in the wheeling rate is the average percentage losses
5 on the Hydro system as determined for 1999 rounded off to the nearest
6 whole point above that determined. This is consistent with the existing
7 agreement with Abitibi Consolidated Inc. as referenced in IC-43.

8

9 The losses in 1999 were as follows:

10

11	Total Energy Supply (Purchased and Produced)	5,877 GWh
12	System Losses (Excluding Distribution)	214 GWh
13	System Losses Percent	3.6%

14