

1 Q. With reference to the transmission losses for 2002 forecast in Budgell's
2 schedule V:

3

4 1. What losses are included?

5 2. If distribution losses are included, quantify the loss.

6 3. Are the proposed adjustments for transformer losses for certain
7 customers reflected in the forecast losses?

8

9 A. 1. Transmission losses are defined as the difference between net generation
10 and metered sales at the customers' delivery points. In the case of Hydro
11 Rural, metering occurs at the bulk delivery points.

12

13 2. Distribution losses are not included in transmission losses.

14

15 3. The proposed adjustments for specifically assigned and customer owned
16 transformers are not reflected in the forecast.