Q. Provide available hydrological data relating to the Roddickton mini-hydro 1 2 plant. 3 4 A. 5 Hydro does not collect this data as it is impractical for such a small run of 6 river plant. The only hydrological data available for the Roddickton minihydro plant is from the initial project analysis. At that time the average flow 7 available for generation was estimated from available stream flow data to be 8 18.9 Mm³ per year. 9