

1 Q. With respect to the runner replacements on Bay d'Espoir units 1 - 6:

2

3 1. Have the replacements resulted in increased production? If so, to  
4 what extent?

5

6 2. Have the replacements resulted in cost savings? If so, in what areas  
7 and what savings each year are attributable to that work?

8

9

10 A. 1. Yes, there has been an increase in production as outlined in the  
11 evidence of R. J. Henderson, page 4 lines 1 to 16.

12

13 2. Yes, there have been savings in the areas of cavitation and corrosion  
14 repairs, blade crack repairs and in the dismantling and reassembly of  
15 the units to make major repairs. The annual savings for all units is  
16 estimated to be \$100,000.