

1 Q. In each of the years 1992 through 2000, on how many occasions has Hydro  
 2 requested Newfoundland Power to operate its stand-by gas turbines and  
 3 diesel units? For how long on each occasion?

4  
 5

6 A. The following table shows the frequency and duration of requests made by  
 7 Hydro to Newfoundland Power to operate its standby gas turbines and diesel  
 8 units from 1992 through 2000.

9

<u>Year</u>	<u>Frequency</u>	<u>Duration</u>
1992	1	34 hours*
1994	6	1 hour 1.5 hours 1.5 hours 7 hours 0.5 hour 5 hours*
1995	2	0.5 hour* 4.5 hours*
1996	1	3 hours
1997	2	0.5 hour* 1.5 hours
1998	4	5 hours 0.5 hour 1.5 hours 3 hours*

10

11

\* Approximated based on fuel used and energy produced.