

1 Q. Provide the lowest historic inflow sequence experienced in Hydro's 50 years
2 of records? In what year did that occur?

3

4

5 A. There are many low inflow sequences of various lengths. The longest low
6 inflow sequence for the 50 years of hydrological record took place for the
7 period June 1959 through to March 1962 and it dictates our reservoir
8 minimum storage targets. It is defined by the period in which our reservoirs
9 will go from the maximum storage level to empty while still maintaining firm
10 energy production output from the hydroelectric plants.