

1 Q. With respect to “lowest historic inflow sequence experienced”, what was that
2 assumption in the forecast for each of the years 1990 - 2000, the number of
3 years data utilized to support that forecast and the actual experience in that
4 year?

5

6

7 A. In all years the hydroelectric production forecast was the then current annual
8 average energy capability which is based on all historic inflow sequences
9 including the lowest sequence. Hydro’s actual experience in inflows for each
10 year since 1990 are provided in the answer to IC-155. These years
11 experienced significantly higher inflows than the lowest historic inflow
12 sequence.