

1 Q. In Hydro's 2002 Forecast Cost of Service was based on the last forty (40)
2 years lowest historic inflow sequence experienced, would the revenue
3 requirement change? If so, how?
4

5
6 A. Under the stated circumstances, hydraulic production for 2002 would
7 decrease by 640 GWh. Thermal production would therefore increase
8 accordingly. This would result in an increase in the total revenue
9 requirement of approximately \$20 million.