

1 Q. Has Hydro's long-term average production from hydraulic generation been
2 adjusted to reflect the changes at Bay d'Espoir referred to at pages 3 - 4 of
3 the evidence of R. J. Henderson?

4

5

6 A. Yes, the conversion factor used for Bay d'Espoir is the average for the years
7 1991 to 1999. The runner replacements were completed over the period
8 1993 to 1996 and the impact of the new runner efficiencies is reflected in the
9 conversion factor experience over that period.