

1 Q. Explain how the changes in bulk metering for bulk deliveries to Hydro's Rural
2 Interconnected Customers affects the forecast for bulk deliveries to that class
3 starting in 2002.

4

5 A. The change in bulk metering (i.e. to allocate GNP 138 kV transmission
6 losses to common from specifically assigned) reduces Hydro Rural
7 Interconnected bulk deliveries by 10 GWh in 2002.