

1 Q. Provide detailed particulars and calculations showing how a credit was
2 applied by Hydro in favour of Newfoundland Power in respect of the
3 Southside Steam Plant when the plant was functioning.

4
5

6 A. Please refer to NP-126. When the Southside Steam Plant was functioning,
7 the Installed Thermal Capacity was 30 MW rather than 0.0 MW as is
8 currently the case. The calculation methodology was the same except
9 reserve was set at 18% in 1992.

10

11	Installed Capacity	(MW)
12	Thermal	30.0
13	Less 18% Reserve*	<u>4.6</u>
14	Capacity Credit	25.4

15

16 * Note - expressed as a percent of load and calculated as

17 30 (1-1/1.18)