

1 Q. Confirm the extra net capacity and firm capability assumed for Deer Lake in
2 Schedule XII of H.G. Budgell, and confirm that this explains why this
3 schedule is not otherwise consistent with the combination of Schedule XI and
4 X. (If Deer Lake does not explain the difference noted, explain this
5 difference).

6

7 A. The continuation of the 60 Hz turbine upgrade program at Deer Lake does
8 explain the difference between the net capacity and firm capability numbers
9 in Schedule XII and the combination of those numbers in Schedules X and
10 XI.

11

12 Hydro has assumed, based on information from the customer, that the
13 remaining three 60 Hz turbines will be upgraded by the Fall of 2003 with
14 additional net capacity of 0.5 MW per unit and additional firm capability of 4.7
15 GWh per unit.