

1 Q. Provide monthly LOLH calculations for 2002 omitting the generation provided  
2 by the Roddickton Mini-Hydro, the St. Anthony Diesel, the Hawke's Bay  
3 diesel and the Roddickton diesel.

4  
5

6 A. The monthly LOLH calculations for 2002 for the Island Interconnected  
7 System with the Roddickton Mini-Hydro, St. Anthony Diesel, Hawke's Bay  
8 diesel and Roddickton diesel removed from the system capability are shown  
9 below:

10

	LOLH
	(hours)
13 Jan	1.22133
14 Feb	3.05730
15 Mar	0.25607
16 Apr	0.00374
17 May	0.00126
18 Jun	0.00009
19 Jul	0.00000
20 Aug	0.00000
21 Sep	0.00000
22 Oct	0.00022
23 Nov	0.02583
24 Dec	0.61613