

1 Q. In Brickhill's schedule 2.2A, line 22, column 3, \$1,204,121 of distribution
2 substations are classified as production demand.

3

4 a. List the substation(s) involved.

5

6 b. Explain why the substation(s) is classified as production demand
7 rather than distribution.

8

9

10 A. a. The substations involved are:

11	Roddickton	\$369,929
12	St. Anthony	<u>834,192</u>
13	Total	\$1,204,121

14

15 b. Roddickton: These low voltage distribution assets are used to
16 connect the two 850 kW mobile diesel generators to the Roddickton
17 Terminal Station.

18

19 St. Anthony: When this system was interconnected, a high voltage
20 terminal station was established at St. Anthony connecting the 69 kV
21 transmission to the local distribution system. The assets referred to
22 above are low voltage distribution assets used to connect the
23 generation to the high voltage terminal station.

24

25 In both cases, if there were no generation at these locations, the
26 distribution assets would not be required. Hydro has therefore
27 functionalized them to generation.