

- 1 Q. Provide hydroelectric production, thermal production, and energy purchases
2 by year from 1992 to 2000 and forecast for 2001 and 2002 in the format set
3 forth in RJH, Schedule V.
4
5 A. See attached tables:

NEWFOUNDLAND AND LABRADOR HYDRO ISLAND INTERCONNECTED SYSTEM ENERGY SUPPLY 1992 - 1995									
	Filed PUB 1991	1992 Actual	Variance from 1992 Forecast	1993 Actual	Variance from 1992 Actual	1994 Actual	Variance from 1993 Actual	1995 Actual	Variance from 1994 Actual
	GWh	GWh	GWh	GWh	GWh	GWh	GWh	GWh	GWh
Hydro-electric	4,211.91	4,221.58	9.67	4,439.03	217.45	5,043.58	604.55	4,392.54	(651.05)
Thermal Generation	1,844.19	1,704.79	(139.40)	1,559.19	(145.60)	778.19	(781.00)	1,533.87	755.68
Energy Purchased	0.00	4.71	4.71	6.42	1.71	2.80	(3.61)	1.84	(0.96)
Less Synchronous Condenser Use	0.00	2.24	2.24	4.66	2.42	6.40	1.74	1.00	(5.40)
Total Energy Supply	6,056.10	5,928.84	(127.26)	5,999.98	71.14	5,818.18	(181.80)	5,927.25	109.08

NEWFOUNDLAND AND LABRADOR HYDRO ISLAND INTERCONNECTED SYSTEM ENERGY SUPPLY 1996- 1999								
	1996 Actual	Variance From 1995 Actual	1997 Actual	Variance From 1996 Actual	1998 Actual	Variance From 1997 Actual	1999 Actual	Variance From 1998 Actual
	GWh	GWh	GWh	GWh	GWh	GWh	GWh	GWh
Hydro-electric	4,573.58	181.04	4,629.50	55.92	4,262.53	(366.97)	4,802.55	540.55
Thermal Generation	1,406.49	(127.38)	1,530.85	124.36	1,262.59	(268.27)	919.15	(343.43)
Energy Purchased	10.41	8.57	6.14	(4.27)	199.98	193.84	161.52	(38.46)
Less Synchronous Condenser Use	1.94	0.95	2.10	0.16	7.36	5.25	6.31	(1.04)
Total Energy Supply	5,988.54	61.28	6,164.39	175.86	5,717.73	(446.66)	5,876.91	159.18

NEWFOUNDLAND AND LABRADOR HYDRO ISLAND INTERCONNECTED SYSTEM ENERGY SUPPLY 2000-2002						
	2000 Actual	Variance From 1999 Actual	2001 Forecast	Variance From 2000 Actual	2002 Forecast	Variance From 2001 Forecast
	GWh	GWh	GWh	GWh	GWh	GWh
Hydro-electric	5,016.71	214.16	4,271.67	(745.04)	4,271.67	0.00
Thermal Generation	968.30	49.15	1,974.93	1,006.63	2,162.43	187.50
Energy Purchased	161.18	(0.34)	145.90	(15.28)	145.90	0.00
Less Synchronous Condenser Use	4.75	(1.57)	0.00	(4.75)	0.00	0.00
Total Energy Supply	6,141.45	264.53	6,392.50	251.05	6,580.00	187.50