

- 1 Q. Provide the annual production efficiency (in kWh per barrel) for the Holyrood  
2 generating facility for each year for the period 1992 to 2000.  
3  
4 A. The annual net production efficiencies for the Holyrood thermal generating  
5 station for 1992 to 2000 are as follows:

<b>YEAR</b>	<b>kWh/bbl</b>
1992	597.3
1993	606.5
1994	579.3
1995	622.3
1996	611.0
1997	629.5
1998	618.8
1999	577.1
2000	609.6