

- 1 Q. Provide copies of the reports on the Conditions Surveys:
2
- 3 (a) Completed in 1999 of Holyrood Thermal Units 1 and 2 and the
4 Hardwoods and Stephenville Gas Turbines (JCR, page 12, line 9);
5 (b) Completed on the Transmission lines on the Avalon (JCR, page 12,
6 line 28).
7 (c) Were the results of the Conditions Surveys reviewed by external or
8 independent experts (JCR, page 12, lines 9 and 28)? If so, who?
9 Provide any written reports by the external or independent experts.
10 (d) What service life will be utilized on transmission lines receiving major
11 upgrades as part of the 2002 capital program (JCR, page 13, line 1)?
12
- 13 A. (a) A copy of the Condition Survey completed in 1999 is attached.
14 (b) See attached report entitled "Residual Life Assessment of Upgraded
15 Transmission Lines on the Avalon Peninsula".
16 (c) The results of the Condition Surveys were not reviewed by external or
17 independent experts.
18 (d) Transmission lines receiving major upgrades, as part of the 2002
19 capital program will have a service life of 50 years once the upgrades
20 are completed.