

- 1 Q. Reconcile the 1026.8 MW peak forecasted for 2002 (HGB, Schedule V) and  
 2 the 2 CP production demand data (JAB-1, page 38).  
 3  
 4 A. See table below.

<b>Reconciliation of Newfoundland Power Demand Forecast Versus 2CP (KW)</b>			
	January	December	2CP - Total
NP as per JAB-1, page 38	989,280	989,288	1,978,568
Demand as per Forecast	1,026,791	1,026,791	
Adjustment to include load supplied by NP	46,960	46,960	
Generation Credit	(120,500)	(120,500)	
Allocated Losses to Transmission side of Generation	36,029	36,037	
Generation CP	989,280	989,288	1,978,568