

1 Q. Provide a breakdown of the firm energy capability forecast in GWh by
2 hydroelectric, thermal and energy purchases for the years 2001 to 2010
3 (HGB, Schedule XII).

4

5

6 A. A breakdown of the firm energy capability in GWh by hydroelectric, thermal
7 and purchases for the years 2001 to 2010 is detailed in the attached table:

**Newfoundland and Labrador Hydro
Island Interconnected System**

Annual Firm Energy Capability (GWh)

<u>Year</u>	<u>Total (Schedule XII)</u>	<u>Hydroelectric</u>	<u>Thermal</u>	<u>Purchases</u>
2001	8,275	5,172	2,996	107
2002	8,280	5,177	2,996	107
2003	8,442	5,289	2,996	157
2004	8,715	5,402	2,996	317
2005	8,715	5,402	2,996	317
2006	8,715	5,402	2,996	317
2007	8,715	5,402	2,996	317
2008	8,715	5,402	2,996	317
2009	8,715	5,402	2,996	317
2010	8,715	5,402	2,996	317