

1 Q. RE: p. B-16 Replace Control Cables – Bay d'Espoir (\$131,000)

2

3 8.1 Does the company intend to replace the other control cables at this  
4 site or at other sites with fibre optic cables at a future date?

5

6

7 A. 8.1 At present Hydro has no plans to replace other control cables at this  
8 site or any other site with fibre optic cable. This cable is being  
9 replaced because of damage caused by lightning.