

1 Q. RE: p.B-34 Purchase and Install Digital Fault Recorder – Stony Brook
2 (\$92,000)

3

4 25.1 During the period from 1995 – 2000, what are the reliability statistics
5 of the company with regard to momentary and sustained outages in
6 the Stony Brook area?

7

8 A. 25.1 During the period from 1995 – 2000, the momentary and sustained
9 outages at the Stony Brook Terminal Station were as follows:

10

11 Momentary Outages18

12 Sustained Outages 19

13 37

14 It should be noted that these numbers do not include statistics for
15 Newfoundland Power’s 138kV lines, 130 L and 133 L, or incidents of
16 single pole reclosing. These, however, would be recorded with the
17 proposed digital fault recorder.