

1 Q. RE: p.B-52 Replace 135 kW Diesel Unit No. 266 – William’s Harbour  
2 (\$11,000; Future \$288,000)

3

4 35.1 To June 30, 2001, what units are in use at William’s Harbour? What  
5 are their ages, sizes, operating hours and scheduled replacement  
6 dates?

7

8

9 A. 35.1 The information on the William’s Harbour plant is as follows:

10

11

12

William’s Harbour Diesel Plant:

Diesel Unit	KW Rating	Total Engine Hours	Unit Age	Scheduled Replacement Date
# 2057 (G1)	100	2,918	2 years	2021
# 266 (G2)	136	80,222	26 years	2003
# 290 (G3)	136	63,741	25 years	2005

13