

1 Q. RE: p.B-54 Replace 250 kW Diesel Unit No. 293 – Rigolet (Previous  
2 \$11,000; \$301,000)

3

4 37.1 To June 30, 2001, what units are in use at Rigolet? What are their  
5 ages, sizes, operating hours and scheduled replacement dates?

6

7 A. 37.1 To June 30, 2001 the following is the information on the units in  
8 Rigolet.

9

10

Engine data for Rigolet

Unit No.	KW	Purchase Date	Total Hours	Replacement Date
223	250	1978	77,694	To be reviewed in 2002 as part of 5 year capital plan
2049	122	1998	4820	Unscheduled
293	250	1974	90,374	2002
2051	545	1998	14,993	Unscheduled

11