

1 Q. RE: p.B-56 Purchase and Install Fire Alarm System – Black Tickle (\$50,000)

2

3 39.1 Is there currently a fire alarm system at the Black Tickle generating  
4 plant?

5

6 39.2 Are there currently in the Hydro system any plants at which there are  
7 no fire alarm systems in place? What plans does the company have  
8 for dealing with any such plants?

9

10 A. 39.1 There is no fire alarm system in the Black Tickle plant at present.

11

12 39.2 Besides Black Tickle, there are nine other isolated diesel plants which  
13 do not have fire alarm systems. Hydro plans to install fire alarm  
14 systems in these locations over the next five years.