

1 Q. RE: RJH p. 3

2

3 52.1 Has the increased annual energy capacity on the Island Interconnect
4 (*sic.*) System resulted in additional capital expenditures for expansion
5 or upgrade of transmission lines or terminal stations? If so, please
6 provide details.

7

8 A. 52.1 The increased annual energy capability and increased net capacity
9 referenced in lines 7 to 18 of page 3 of R. J. Henderson's evidence did
10 not require additional capital expenditures for expansion or upgrade of
11 transmission lines or terminal stations.

12

13 The increase in capacity referenced in lines 20 to 22 of page 3 was as
14 a result of capital expenditures to interconnect the Roddickton and St.
15 Anthony system loads.