

1 Q. a) What would the average cost of energy per MWh, including
2 appropriate allowance for capital cost, of an additional unit at the
3 Holyrood?

4
5 b) What would be the estimated conversion factor?

6
7
8 A. a) For reasons of commercial confidentiality, Hydro cannot provide this
9 information. Moreover, this information is not material or relevant to
10 the understanding of the issues with this application.

11
12 b) The conversion factor for a new conventional steam unit at Holyrood
13 would be dependent on the unit's production level. At best, it is
14 estimated to be in the range of 638 kWh/bbl.