

- 1 Q. Please reproduce Table 3 on page 15 and Table 4 on page 16 of
 2 Transmission and Rural Operations Evidence by David W. Reeves to include
 3 a column that shows numbers excluding planned outages?
 4
 5
 6 A. See tables below.

| Interconnected Rural Systems Service Continuity | | | | |
|--|---|----------------------------------|-----------------------------------|----------------------------------|
| Year | SAIFI Interruptions / Customer | | SAIDI Hours / Customer | |
| | Incl. Planned Outages | Excl. Planned Outages | Incl. Planned Outages | Excl. Planned Outages |
| 2000 | 7.09 | 5.44 | 14.34 | 10.14 |
| 2001 | 6.58 | 3.47 | 10.42 | 9.10 |
| 2002 | 7.35 | 6.23 | 12.29 | 7.90 |
| | | | | |
| 3 Year Avg. | 7.01 | 5.05 | 12.36 | 9.04 |

| Isolated Rural Systems Service Continuity | | | | |
|--|---|----------------------------------|-----------------------------------|----------------------------------|
| Year | SAIFI Interruptions / Customer | | SAIDI Hours / Customer | |
| | Incl. Planned Outages | Excl. Planned Outages | Incl. Planned Outages | Excl. Planned Outages |
| 2000 | 12.66 | 10.36 | 12.39 | 8.61 |
| 2001 | 13.57 | 12.14 | 8.44 | 6.51 |
| 2002 | 23.75 | 20.29 | 22.84 | 18.49 |
| | | | | |
| 3 Year Avg. | 16.66 | 14.26 | 14.56 | 11.20 |