

1    Q.    On page 15, Table 4 of Mr. Haynes' Pre-filed Evidence, are the generating  
2           stations included in the CEA sample of the same approximate size and  
3           capacity factor as Holyrood?

4

5

6    A.    The CEA sample of all oil-fired fossil units has 70% of the units in the size  
7           range of Holyrood which is 100-199 MW. The CEA data does not provide  
8           unit capacity factors. However, it does provide operating factors (percent of  
9           time the unit is operating). This CEA sample has an average operating factor  
10          of 35.93%. The Holyrood plant in the 1997 to 2002 period had an operating  
11          factor of 56.86%.