| 1 | Q. | On page 27, lines 5 to 7 of Mr. Haynes' Pre-filed Evidence, he indicates that |
|----|----|---|
| 2 | | NLH purchased an additional 8.6 GWh of secondary energy as a result of |
| 3 | | unforeseen shutdowns at Stephenville and Grand Falls paper mills. Please |
| 4 | | provide a comparison of the costs of these purchases versus the savings |
| 5 | | from displaced generation. |
| 6 | | |
| 7 | | |
| 8 | Α. | As outlined in Schedule X of the Production Evidence, in 2002 \$155,000 was |
| 9 | | charged for the 8.58 GWh of secondary energy, an average price of \$0.0180 |
| 10 | | per kWh. The cost to produce this equivalent energy per kWh at Holyrood, in |
| 11 | | 2002 using the data from Schedule VII was \$ 0.0472 per kWh. |