

1     Q.     (a)   In what way, if any, does the Winter Availability Contract between  
2                   CFLCo and Hydro-Quebec affect the supply of energy to the Labrador  
3                   Interconnected System?  
4

5           (b)   Similarly, does energy consumption of the Labrador Interconnected  
6                   System affect the amount available for sale under that contract?  
7  
8

9     A.     (a)   Hydro has purchased the maximum recall available from CF(L)Co,  
10               which is 300 MW at the Quebec Labrador border. The Winter  
11               Availability Contract is net of the 300 MW recall and this does not  
12               affect the supply of energy to the Labrador Interconnected customers.  
13

14           (b)   No. Energy consumption on the Interconnected Labrador system  
15               does not affect the Winter Availability Contract.