

1    Q.    Provide Holyrood capacity factor data for the five years 1996 – 2000 and for  
2           the five years 1997-2001 and 1998-2002 in the same format as in  
3           Greneman's schedule 4.3 together with a copy of Schedule 4.3 to Brickhill's  
4           evidence in the 2001 General Rate Application.

5

6

7    A.    Please see attached.

**NEWFOUNDLAND & LABRADOR HYDRO**  
**Holyrood Capacity Factor**

|          | 1              | 2                    | 3                 | 4                    | 5                   |
|----------|----------------|----------------------|-------------------|----------------------|---------------------|
| Line No. | Year           | Net Production (kWh) | Net Capacity (MW) | Net Production Hours | Net Capacity Factor |
| 1        | 1996 Actual    | 1,403,596,120        | 466               | 8,784                | 34.29%              |
| 2        | 1997 Actual    | 1,531,300,920        | 466               | 8,760                | 37.51%              |
| 3        | 1998 Actual    | 1,263,264,060        | 466               | 8,760                | 30.95%              |
| 4        | 1999 Actual    | 919,801,520          | 466               | 8,760                | 22.53%              |
| 5        | 2000 Actual    | 970,283,280          | 466               | 8,784                | 23.70%              |
| 6        | 5-Year Average | 1,217,649,180        | 466               | 8,770                | 29.80%              |
| 7        | 1997 Actual    | 1,531,300,920        | 466               | 8,760                | 37.51%              |
| 8        | 1998 Actual    | 1,263,264,060        | 466               | 8,760                | 30.95%              |
| 9        | 1999 Actual    | 919,801,520          | 466               | 8,760                | 22.53%              |
| 10       | 2000 Actual    | 970,283,280          | 466               | 8,784                | 23.70%              |
| 11       | 2001 Actual    | 2,098,489,700        | 466               | 8,760                | 51.41%              |
| 12       | 5-Year Average | 1,356,627,896        | 466               | 8,765                | 33.21%              |
| 13       | 1998 Actual    | 1,263,264,060        | 466               | 8,760                | 30.95%              |
| 14       | 1999 Actual    | 919,801,520          | 466               | 8,760                | 22.53%              |
| 15       | 2000 Actual    | 970,283,280          | 466               | 8,784                | 23.70%              |
| 16       | 2001 Actual    | 2,098,489,700        | 466               | 8,760                | 51.41%              |
| 17       | 2002 Actual    | 2,385,262,000        | 466               | 8,760                | 58.43%              |
| 18       | 5-Year Average | 1,527,420,112        | 466               | 8,765                | 37.40%              |

**NEWFOUNDLAND & LABRADOR HYDRO**  
**#NAME?**  
**Holyrood Capacity Factor**  
**From Exhibit JAB-1, May 2001**

|          | 1              | 2                    | 3                 | 4                    | 5                   |
|----------|----------------|----------------------|-------------------|----------------------|---------------------|
| Line No. | Year           | Net Production (kWh) | Net Capacity (MW) | Net Production Hours | Net Capacity Factor |
| 1        | 1997 Actual    | 1,531,300,920        | 466               | 8,760                | 37.51%              |
| 2        | 1998 Actual    | 1,263,264,060        | 466               | 8,760                | 30.95%              |
| 3        | 1999 Actual    | 919,801,520          | 466               | 8,760                | 22.53%              |
| 4        | 2000 Actual    | 970,283,280          | 466               | 8,784                | 23.70%              |
| 5        | 2001 Forecast  | 1,971,340,000        | 466               | 8,760                | 48.29%              |
| 6        | 5-Year Average | 1,331,197,956        | 466               | 8,765                | 32.59%              |