

1 Q. Recalculate the LOLH as shown on Table 8 in the evidence of Mr. Haynes
2 assuming that the Corner Brook and Paper and Exploits River capacity did
3 not exist and assuming that the total load was reduced by an amount equal
4 to the amount of load which those facilities are forecast to meet in each year
5 and provide the monthly breakdown of those LOLH figures.

6
7
8 A. Please see attached table for the annual and monthly breakdowns of LOLH
9 values assuming that the CBPP and ACCC hydroelectric capacity does not
10 exist and with the load met by these resources also removed.

Island Interconnected System Existing Generating Capacity Net of CBPP and ACCC Hydroelectric Capacity and Corresponding Load LOLH (hrs/yr)													
Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
2003	0.30004	0.10437	0.03294	0.00070	0.00002	0.00000	0.00000	0.00000	0.00000	0.00038	0.00505	0.16858	0.61207
2004	0.58472	0.19028	0.05170	0.00132	0.00005	0.00000	0.00000	0.00000	0.00000	0.00079	0.00871	0.24853	1.08612
2005	0.62354	0.23144	0.05630	0.00150	0.00006	0.00002	0.00000	0.00000	0.00000	0.00090	0.00964	0.26763	1.19103
2006	0.70511	0.26444	0.06456	0.00181	0.00008	0.00002	0.00000	0.00000	0.00000	0.00105	0.01118	0.30069	1.34892
2007	0.84334	0.32177	0.07977	0.00240	0.00011	0.00003	0.00000	0.00000	0.00000	0.00143	0.01425	0.36072	1.62381
2008	0.99201	0.33570	0.09659	0.00304	0.00014	0.00003	0.00000	0.00000	0.00000	0.00188	0.01770	0.42537	1.87246
2009	1.18743	0.46624	0.11826	0.00396	0.00019	0.00004	0.00000	0.00000	0.00000	0.00239	0.02212	0.50657	2.30721
2010	1.46364	0.58304	0.14921	0.00532	0.00026	0.00006	0.00000	0.00000	0.00000	0.00318	0.02856	0.61943	2.85270
2011	1.79972	0.72763	0.18844	0.00717	0.00042	0.00008	0.00000	0.00000	0.00000	0.00426	0.03704	0.75958	3.52436
2012	5.44881	1.90711	0.64527	0.03272	0.00251	0.00045	0.00000	0.00000	0.00000	0.01868	0.14053	2.23524	10.43130