

1 Q. What was the actual load factor for the Island Interconnected System in
2 2002?

3

4

5 A. The Island Interconnected System load factor for 2002 was 59% and was
6 calculated based on the Island Interconnected annual peak demand of 1592
7 MW and Island Interconnected load of 8221 GWh.