

1 Q. In each of the years 1992 through 2000, on how many occasions has Hydro
2 interrupted Stephenville ACI pursuant to its interruptible contract? For how
3 long was power interrupted on each occasion?

4

5

6 A. Please refer to table below:

Newfoundland & Labrador Hydro Interruptible B Interruptions				
	Season	Interruptions	Date	Duration (hr:min:sec)
1.	1993/1994	1	12/16/1993	5:15:00
2.	1993/1994	1	12/30/1993	4:15:00
3.	1993/1994	1	01/17/1994	5:45:00
4.	1993/1994	1	02/09/1994	8:45:00
5.	1993/1994	1	02/13/1994	1:15:00
6.	1994/1995	1	12/10/1994	2:15:00
7.	1994/1995	1	12/11/1994	8:00:00
8.	1994/1995	1	02/14/1995	8:30:00
9.	1995/1996	0		
10.	1996/1997	0		
11.	1997/1998	0		
12.	1998/1999	0		
13.	1999/2000	0		
14.	2000/2001	0		