

1 Q. In the System Operating Instructions (Appendix A of JRH-3), please describe
2 what is meant by “Ask Newfoundland Power to curtail any interruptible loads
3 available?”

4

5

6 A. Hydro is aware that Newfoundland Power has an arrangement with some of
7 its customers to interrupt load upon request. This step in the noted System
8 Operating Instruction refers to those loads.