

1 Q. Please show the load forecast for CP, NCP and energy by month for the
2 GNP loads in 2004.

3

4

5 A. For the Operating Load Forecast, the Hydro Rural Island interconnected
6 service territory is forecast as a single entity and therefore includes the GNP.
7 Accordingly, CP and energy by month for GNP loads in 2004 are not
8 available. For the purposes of distribution planning, an annual peak demand
9 forecast is prepared for the various GNP distribution locations. The NCP
10 forecast demands for the GNP distribution systems in 2004 are:

NCP Distribution Demand For GNP in 2004	
Distribution System	KW
Rocky Harbour	4,573
Wiltondale	135
Glenburnie	2,167
Hawkes Bay	7,146
Daniel's Harbour	1,120
Cow Head	1,864
Plum Point	4,197
Bear Cove	5,029
Parsons Pond	889
St. Anthony	7,509
Roddickton	4,007
Main Brook	625