

1 Q. Exhibit JRH-3 indicates the GNP generation units were operated once in
2 support of the Island Interconnected System and once were tested to ensure
3 they were ready. Please indicate the number of times since 1996 that the
4 GNP generation (Hawke's Bay and St. Anthony) operated in support of the
5 local load (i.e. due to transmission of transformation problems on the GNP,
6 etc.).

7
8
9 A. To help support loads local to the generators, the Hawke's Bay and St.
10 Anthony diesel units have operated 112 times since 1996.