

1 Q. Please show the 2004 and 2005 LOLH and Energy Balance if Granite Canal  
2 were not in service.

3

4

5 A. The following table shows the LOLH and Energy Balance with Granite Canal  
6 not in service:

<b>Island Interconnected System Near Term Capability Requirements <i>With Granite Canal Removed From Service</i></b>						
<b><u>Load Forecast</u></b>			<b><u>Existing plus Committed System**</u></b>			
<b><u>Year</u></b>	<b><u>Peak</u></b>	<b><u>Energy</u></b>	<b><u>Net Capacity</u></b>	<b><u>Firm Capability</u></b>	<b><u>LOLH</u></b>	<b><u>Energy Balance</u></b>
	(MW)	(GWh)	(MW)	(GWh)	(Hrs/Yr)	(GWh)
2004	1,602	8,504	1,879	8,490	2.3	(14)
2005	1,607	8,512	1,879	8,490	2.6	(22)

\*\* Net of Granite Canal