

1 Q. Please indicate the expected retirement date of each of the gas turbines.

2

3

4 A. Each of Hydro's gas turbines on the Island Interconnected System has
5 exceeded its expected economic life of 25 years. However, considering the
6 overall condition of these units, Hydro expects that they could be serviceable
7 for another 15 to 20 years.