

1 Q. Please indicate the expected retirement date of each of the diesel
2 generators.

3

4

5 A. Each of Hydro's diesel generators on the Island Interconnected System has
6 exceeded its expected economic life of 20 years. However, considering the
7 overall condition of these units, Hydro expects that they could be serviceable
8 for another 10 to 12 years.