

- 1 Q. Please provide a copy of Table 3-3 (page 12 from Exhibit JRH-3) showing all
2 figures assuming the 46 MW of Interruptible B power had been maintained.
3
4
5 A. Please refer to the following table:

Year	Existing plus Committed System <i>46 MW Interruptible 'B' Contract with ACCC-Stephenville through 2012</i>						
	Base Case		Less GNP	Less Doyles- Port aux Basques	Less Burin Peninsula	Less GNP, Doyles-Port aux Basques and Burin Peninsula	
	LOLH hrs/yr	Energy Balance GWh	LOLH hrs/yr	LOLH hrs/yr	LOLH hrs/yr	LOLH hrs/yr	Energy Balance GWh
2003	0.6	265	0.8	0.9	1.2	2.2	214
2004	0.9	202	1.2	1.2	1.6	2.9	151
2005	1.0	194	1.3	1.3	1.8	3.2	143
2006	1.1	150	1.5	1.5	2.1	3.6	99
2007	1.3	100	1.8	1.8	2.5	4.3	49
2008	1.5	53	2.0	2.0	2.8	4.8	2
2009	1.9	(10)	2.5	2.6	3.5	6.0	(61)
2010	2.4	(88)	3.2	3.2	4.3	7.3	(138)
2011	3.0	(159)	3.9	3.9	5.3	8.9	(210)
2012	9.2	(603)	11.7	11.7	15.2	24.0	(654)