

1 Q. Please describe the testing of the GNP diesel generation as outlined on
2 page 16 of JRH-3. Is it necessary to test these units in advance of
3 dispatching them?
4

5

6

7 A. The testing was simply the starting of the plants to ensure that they would be
8 available if required later on that day. It is not necessary to test the units prior
9 to dispatching them but was done as a precautionary measure to ensure a
 secure supply to customers on such a high load day.