

1 Q. Please indicate all occasions since 2000 when NP's generation has
2 been dispatched by Hydro to cover system capacity peaks, including the
3 date and time, the duration, the number of MW and MW.h dispatched, any
4 amounts paid by Hydro to NP (showing the full calculation of any amounts
5 paid).

6

7

8 A. The only occasion since 2000 that NP's generation was dispatched by Hydro
9 to cover system capacity peaks was on January 30, 2003. The details are
10 as follows:

11

12	Start Time	11:04 hours
13	Duration	one hour 32 minutes
14	Capacity	40 MW
15	Energy	32 MWh
16	Fuel	13,792 liters
17	Cost	\$5,020.28